



OFFICE OF CAPITAL PLANNING, DESIGN, AND CONSTRUCTION  
300 POMPTON ROAD • WAYNE, NEW JERSEY 07470-2103  
973.720.2548 FAX 973.720.2829 • WWW.WPUNJ.EDU

## **ADDENDUM NO 1**

TO: All Prospective Bidders  
DATE: April 12, 2017  
PROJECT: Hillside Hall Elevator Modification (WP-17-06-36)

This Addendum No. 1 forms a part of the contract bidding documents and answers all questions submitted regarding the bidding documents. Please acknowledge receipt of this Addendum No. 1 on Bid Document Checklist (WPU01) and Bid Form (WPU03) included in the Bid Document package.

### Questions and Answers:

- Q1. Bidder could not find any pictures or description of materials for Car Enclosure.  
**A1. Photos of the finishes desires are located under Reference Documents in the folder labeled Overlook Elevator Cab Interior Photos on the website at <http://www.wpunj.edu/capital-planning/rfp.html>.**
- Q2. In reference to the cab enclosure, is there a specific cab allowance.  
**A2. There is no specific cab allowance.**
- Q3. What is the finish on the hoistway doors?  
**A3. The finish of the hoistway doors shall match the stainless steel of the new car interior doors.**
- Q4. What is the time of performance?  
**A4. The elevators shall be approved by the NJDCA for legal operation by August 11, 2017.**