



**WILLIAM
PATERSON
UNIVERSITY**

OFFICE OF CAPITAL PLANNING, DESIGN, AND CONSTRUCTION
300 POMPTON ROAD • WAYNE, NEW JERSEY 07470-2103
973.720.2548 FAX 973.720.2829 • WWW.WPUNJ.EDU

ADDENDUM NO 1

TO: All Prospective Bidders
DATE: January 26, 2017
PROJECT: Hunziker Wing Audio Visual Equipment & Integration
(WP-14-14-14)

This Addendum No. 1 forms a part of the contract bidding documents and answers all questions submitted regarding the bidding documents. Please acknowledge receipt of this Addendum No. 1 on Bid Document Checklist (WPU01) and Bid Form (WPU03) included in the Bid Document package.

Questions and Answers:

- Q: Extron 26-667-01 is retired. Please specify replacement.
A. The replacement Extron cable is 26-663-02 (it is the same 1.5 ft. length).
- Q. Who is responsible for the program and programming test of the systems?
A. William Paterson University will be responsible for the programming. The code is a university standard and conforms to the drawings provided. Code will be provided for touch panel and control system testing when requested. In addition, the RS-232 wiring is labeled on the drawings to minimize wiring inconsistency.
- Q. Please clarify who is providing and installing the screens for Rooms 235 and 215. They appear in the spread sheet, but in other rooms the screens, etc. are provided and installed by GC.
A. The screens in 215 and 235 will be provided and installed by the general contractor performing the building renovation.. The AV contractor is responsible to run control cabling to the low voltage interface as well as terminate the cabling and test.

Q. Classroom Type 133 (qty 9) Spec has AV providing the LCV-IV and GC providing screen. Please confirm or clarify.

A. LVC-IV units are not necessary in Classroom Type 133 because the general contractor is providing screens with low voltage control built into screen housing.

Q. Room type 133. Please clarify duplication of Chief RPMAU.

Classroom-133 AA In Room Video-Video Projection	Threaded Rod; Kindorf above ceiling support assembly for Projection Screen	Chief Manufacturing	RPMAU
Classroom-133 AA In Room Video-Video Projector	Access/ Series V Electric Motorized Video Projection Screen; 133" diagonal, Matt White XT1000V, 16:9 aspect ratio	By GC	Part # 140030QU
Classroom-133 AA In Room Video-Video Projection	Low Voltage Interface	Draper Inc	LVC-IV
Classroom-133 AA In Room Video-Video Projection	Inverted Projection Mount	Chief Manufacturing (BY GC)	RPMAU (BY GC)

A. The RPMAU mounts are a necessary component of the pipe mount assembly. The projector attaches to the RPMAU, which attaches to a threaded pipe, which attaches to a Chief CMA 330 (see Reference Document No. 1). The CMA 330 attaches to a ceiling-mounted unistrut/Kindorf. It is recommended to use the CMA 330 as the offset allows for easy cable install down the pipe. The AV Contractor is to furnish the CMA 330 and threaded pipe (at custom lengths) to the General Contractor for installation.

Q. Can you provide bidder list?

A. The list is public notice has been posted on the website

Q. Clarify union and/or prevailing wage.

A. The successful bidder is required to execute a Project Labor Agreement with the Passaic County Building and Construction Trades Council, AFL-CIO. See Reference Document No. 2 for the PLA Agreement, and Reference Document No. 3 for the Signature Page.

Q. Clarify Section IB 1.9 – Do subcontractors need to furnish performance bond? And is the performance bond for subs, if required, due with bid or after award.

A. Subcontractors do not need to furnish a performance bond.

- Q. Please advise why a Chief certification is required of A/V vendor when the Chief mounts are being provided and installed by the GC.
- A. Certification is required to ensure proper understanding of installation and integration of mounts and brackets by the AV contractor.
- Q. Please confirm that the following clause regarding the bid bond/certified check is applicable to this RFP?
IB 5.1 Each proposal shall be accompanied by a Bid Bond or by a certified check, made payable to the University, equal to or greater than ten percent (10%) of the amount of the proposal, as evidence of good faith, which guarantees that if the proposal submitted by the Bidder is accepted, the Bidder will enter into the Contract and furnish the required Documents and Surety Bonds.
- A. The clause is applicable to the bid.
- Q. Is the following clause applicable to firms that are not using subcontractors?
IB 7.2 The successful Bidder shall furnish within ten (10) calendar days after Notice of Award a Performance Bond in statutory form in an amount equal to one hundred percent (100%) of the total Contract Price as security for the faithful performance of this Contract and also a Payment Bond in statutory form in amount equal to one hundred percent (100%) of the Contract Price as security **for the payment of all persons and firms performing labor and furnishing materials** in connection with this contract.
- A. Yes.