



*A Service Disabled Veteran
Owned Small Business*

TTI Environmental Incorporated
1253 N. Church Street
Moorestown, New Jersey 08057
Tel: 856-840-8800
Fax: 856-840-8815

INSPECTION, SAMPLING AND ANALYSIS

of

Hunziker Hall
300 Pompton Road
Wayne, New Jersey

for

ASBESTOS-CONTAINING BUILDING MATERIAL

conducted at the request of

Mr. Rick Stomber
VP of Capital Planning, Design and Construction
William Paterson University
300 Pompton Road
Wayne, New Jersey

TTI Project No. 14-1532

September 14, 2015



Asbestos Inspection

William Paterson University

Hunziker Hall

TTI Project No. 14-1532

September 14, 2015

Page 2 of 6

TABLE OF CONTENTS

	<u>Page</u>
I. EXECUTIVE SUMMARY	3
II. INTRODUCTION	4
III. INSPECTION, SAMPLING AND ANALYSIS METHODOLOGY.....	5
A. Inspection Methodology	
B. Sampling and Analysis Methodology	

Appendix A: Homogenous Material ID List

Appendix B: Asbestos Summary

Appendix C: Material Reports and Analytical Data

Appendix D: Non Asbestos Material Summary



Asbestos Inspection

William Paterson University

Hunziker Hall

TTI Project No. 14-1532

September 14, 2015

Page 3 of 6

I. EXECUTIVE SUMMARY

TTI Environmental, Inc. (TTI) performed a non-destructive asbestos inspection throughout the Hunziker Hall on the campus of William Paterson University in Wayne, New Jersey. The inspection was conducted on December 31, 2014. During the inspection, suspect Asbestos-Containing Building Materials (ACBM) were sampled and quantified.

Laboratory analysis of the suspect materials revealed an asbestos content of greater than one percent (1%) in the following materials or the materials are assumed to contain asbestos:

Material
<ul style="list-style-type: none">• Pipe insulation• Fitting Insulation associated with Fiberglass Pipe Insulation• 12" Beige with Brown Floor Tile• 12" Tan with Black Floor Tile/Mastic• Exterior Window Caulk• 9" Red Floor Tile/Mastic (assumed to contain asbestos)• 9" Gray Floor Tile/Mastic (assumed to contain asbestos)• 9" Tan with Black Floor Tile/Mastic (assumed to contain asbestos)• Fire Doors (assumed to contain asbestos)• Vibration Collar (assumed to contain asbestos)• Glue associated with Chalkboards (assumed to contain asbestos)• Exterior Boiler Room Window Caulk• 9" Brown Floor Tile/Mastic• Dumb Waiter Access Door

The homogeneous area ID numbers and the complete Asbestos Summary including recommendations can be found in Appendices A and B to this report respectively. For complete information regarding location and sampling of these materials, see Appendix C to this report. In addition, Appendix D contains a summary of those materials determined not to contain asbestos.


Jeffrey Seaman
Project Manager



Asbestos Inspection

William Paterson University

Hunziker Hall

TTI Project No. 14-1532

September 14, 2015

Page 4 of 6

II. INTRODUCTION

TTI was requested by Mr. Richard Stomber, VP of Capital Planning, Design and Construction for William Paterson University to conduct an inspection throughout the Hunziker Hall on the campus of William Paterson University in Wayne, New Jersey. The purpose of the inspection was to locate, sample, and quantify ACBM throughout the site.

The inspection was performed by United States Environmental Protection Agency (USEPA) Accredited Building Inspector, Jeffrey Seaman (#ACC-0911-6-001) who conducted a detailed visual examination of the site for suspect ACBM. This included collecting bulk samples, as well as quantifying both friable and non-friable suspect material.

The results, assessments and conclusions stated in this report are factually representative of the conditions and circumstances we observed on the dates of our inspection. We cannot assume responsibility for any change in conditions or circumstances that occurred subsequent to our inspection.

Certain materials were sampled in a previous asbestos survey performed by Environmental Connections, Inc. (EC), dated September 1999. Where possible TTI utilized these sample results as part of their survey.



Asbestos Inspection

William Paterson University

Hunziker Hall

TTI Project No. 14-1532

September 14, 2015

Page 5 of 6

III. INSPECTION, SAMPLING AND ANALYSIS METHODOLOGY

A. Inspection

The inspection was conducted in accordance with the guidelines established by the Asbestos Hazard Emergency Response Act (AHERA), as set forth in 40 CFR Part 763 of October 30, 1987, and provides a framework for addressing asbestos in public and private schools. The AHERA guidelines represent the most up-to-date inspection and sampling protocol available and as such were utilized while inspecting and sampling.

The USEPA defines "Homogeneous Areas" as those areas of surfacing, thermal system insulation, or miscellaneous materials, which are uniform in color, texture, and assumed to be installed at the same time. The suspected ACBM has been categorized into homogeneous areas. This assigned ID number can be used for cross-referencing between each section of the report.

For the purposes of this inspection, suspect ACBM has been placed in three material categories: surfacing, thermal and miscellaneous.

Surfacing materials are those that are sprayed-on, troweled-on or otherwise applied to surfaces.

Thermal materials are those applied to heat pipes or other structural components to prevent heat loss or gain or prevent water condensation. Thermal materials are characterized by their form or composition.

For example, block pipe insulation is preformed magnesia and/or fibrous material molded for piping and usually covered with a canvas jacket stitched at the seams. It can be identified as hard to the touch when the jacket is intact or white and fibrous when exposed by a breach in the jacket. Cardboard pipe insulation when exposed from its protective jacket consists of layers of brown or gray cardboard pressed together and is typically found on domestic cold water piping. Air-cell is corrugated gray cardboard in layers, usually preformed for the diameter of the pipe in 2 to 3 foot sections and may have a canvas jacket. The block type pipe insulation is typically used where a high coefficient of insulation is desired or required.

Pipe fitting insulation on pipe runs insulated with fiberglass and which contain asbestos are usually hand molded mud applied to the fitting and may have a canvas wrapping over the material. The newer non-asbestos pipe fitting insulation is typically fiberglass covered with a PVC jacket.



Asbestos Inspection

William Paterson University

Hunziker Hall

TTI Project No. 14-1532

September 14, 2015

Page 6 of 6

III. INSPECTION, SAMPLING AND ANALYSIS METHODOLOGY (Continued)

A. Inspection (continued)

Miscellaneous materials are interior building materials on structural components, structural members or fixtures such as floor and ceiling tiles and do not include surfacing material or thermal system insulation.

Please note that destructive or exploratory sampling methods were not employed during the survey. In addition, access was limited to certain areas; therefore, TTI made a prudent effort to identify all accessible asbestos material in the building. During the sampling of floor tile several areas contained multiple layers of tile. Since destructive sampling methods were not employed, in accordance with current USEPA guidelines, tile layers below the surface are assumed to contain asbestos.

Due to the limited access to the materials listed above, quantification of these materials was not conducted during this inspection.

B. Sampling and Analysis

The USEPA requires that bulk samples of suspect ACBM be collected in a manner sufficient to determine whether this material is ACBM. ACBM is any building material, which contains more than 1% asbestos. Generally, for thermal system areas or miscellaneous areas, three (3) bulk samples randomly taken are required to determine that suspected material is not ACBM. Suspect surfacing materials sprayed or troweled-on may require up to nine (9) bulk samples, depending on area size, to determine whether the material is ACBM.

Samples were taken in sufficient quantity in each Homogeneous Area to reliably determine the presence of asbestos. Analysis of samples collected in conjunction with this report was conducted by the following methods:

- . EPA 600/R-93/116
- . Transmission Electron Microscopy (TEM) in accordance with ELAP 198.4, revised 1/11/2005 and EPA-600/R-93/116 Section 2.5



Appendix A

Homogenous Material ID List

List of Materials

William Paterson University

Hunziker Hall

Project No: 14-1532

<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Type of Material</i>	<i>Material Contains >1% Asbestos</i>
01	Interior Window Glazing	Miscellaneous	No
02	Pipe Insulation	Thermal	Yes (prev. sampled)
04	Fittings associated with Fiberglass Pipe Insulation	Thermal	Yes (prev. sampled)
05	Fire Door	Thermal	Yes (assumed)
06	12" Spline Ceiling Tile	Miscellaneous	No (prev. sampled)
08	Ceiling Plaster	Surfacing	No (prev. sampled)
09	Drywall	Miscellaneous	No
10	Joint Compound	Miscellaneous	No
11	Ceramic Tile Grout	Miscellaneous	No
12	Window Sill Slate	Miscellaneous	No
13	Wall Plaster	Surfacing	No
14	2'x2' Lay-in Ceiling Tile	Miscellaneous	No
15	12" Green Floor Tile/Mastic	Miscellaneous	No
16	Black Cove Base Mastic	Miscellaneous	No
17	12" Gray and Green Floor Tile/Mastic	Miscellaneous	No
18	12" Brown Floor Tile/Mastic	Miscellaneous	No
19	12" Beige Floor Tile/Mastic	Miscellaneous	No
20	Brown Cove Base Mastic	Miscellaneous	No
21	9" Red Floor Tile/Mastic	Miscellaneous	Yes (assumed)
22	12" Black Floor Tile/Mastic	Miscellaneous	No
23	12" Tan Floor Tile/Mastic	Miscellaneous	No
24	Glue Dots associated with Chalkboard	Miscellaneous	Yes (assumed)
25	12" Beige with Brown Floor Tile/Mastic	Miscellaneous	Yes
26	12" Tan with Black Floor Tile/Mastic	Miscellaneous	Yes
27	Burgundy Cove Base Mastic	Miscellaneous	No
28	12" White and Black Floor Tile/Mastic	Miscellaneous	No
29	Grey Cove Base Mastic	Miscellaneous	No
31	Brown Duct Insulation	Thermal	No
34	Fiber Board (Behind Radiators)	Miscellaneous	No
35	9" Gray Floor Tile/Mastic	Miscellaneous	Yes (assumed)
36	12" Multi-color Beige Floor Tile/Mastic	Miscellaneous	No
37	12" Pink Floor Tile/Mastic	Miscellaneous	No

List of Materials

William Paterson University

Hunziker Hall

Project No: 14-1532

<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Type of Material</i>	<i>Material Contains >1% Asbestos</i>
38	12" Light Beige Floor Tile/Mastic	Miscellaneous	No
39	Vibration Collar	Miscellaneous	Yes (assumed)
40	2'x4' Lay-in Ceiling Tile	Miscellaneous	No
41	9" Tan with Black Floor Tile/Mastic	Miscellaneous	Yes (assumed)
42	Exterior Window Caulk	Miscellaneous	Yes
43	Exterior Boiler Room Window Glazing	Miscellaneous	No
44	Exterior Brick Mortar	Miscellaneous	No
45	Exterior Boiler Room Window Caulk	Miscellaneous	Yes
46	9" Brown Floor Tile/Mastic	Miscellaneous	Yes
47	Dumb Waiter Access Door	Thermal	Yes (assumed)



Appendix B

Asbestos Summary

Asbestos Summary

Client: **William Paterson University**

Facility: **Hunziker Hall**

Project No.: **14-1532**

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
--------------	-----------------	--------------------	----------------------	---------------	--------------

Basement

Bathroom by Elevator

02 Pipe Insulation 50 LF

Boiler Room

05 Fire Door 115 SF

Costume Shop

02 Pipe Insulation 100 LF

Crawlspace

02 Pipe Insulation 1,175 LF

Elevator Room

02 Pipe Insulation 200 LF

Exterior Boiler Room

45 Exterior Boiler Room
Window Caulk 60 LF

Hallway

02 Pipe Insulation 205 LF

06 12" Spline Ceiling Tile 240 SF

Hallway by Crawlspace Entrance

02 Pipe Insulation 95 LF

08 Ceiling Plaster 350 SF

Hallways

05 Fire Door 120 SF

Mechanical Room

47 Dumb Waiter Access
Door 5 SF

Party Closet Club 29

02 Pipe Insulation 100 LF

Room 139

02 Pipe Insulation 100 LF

Room 23

02 Pipe Insulation 100 LF

Storage

Asbestos Summary

Client: William Paterson University

Facility: Hunziker Hall

Project No.: 14-1532

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
--------------	-----------------	--------------------	----------------------	---------------	--------------

Basement

Storage

02	Pipe Insulation	195	LF
08	Ceiling Plaster	400	SF

Storage outside Bathroom by Elevator Room

02	Pipe Insulation	130	LF
----	-----------------	-----	----

Throughout

04	Fittings associated with Fiberglass Pipe Insulation	60	LF
05	Fire Door	100	SF

First Floor

100 American Federation of Teacher's

06	12" Spline Ceiling Tile	500	SF
----	-------------------------	-----	----

104 UPA Executive Director

06	12" Spline Ceiling Tile	180	SF
26	12" Tan with Black Floor Tile/Mastic	180	SF

105A UPA Conference Room

06	12" Spline Ceiling Tile	250	SF
26	12" Tan with Black Floor Tile/Mastic	250	SF

Bathroom across from Room 35

02	Pipe Insulation	200	LF
----	-----------------	-----	----

Child Development Center

02	Pipe Insulation	100	LF
----	-----------------	-----	----

Elevator

25	12" Beige with Brown Floor Tile/Mastic	35	SF
----	---	----	----

Exterior

42	Exterior Window Caulk	350	LF
----	-----------------------	-----	----

Hallway

06	12" Spline Ceiling Tile	2,500	SF
47	Dumb Waiter Access Door	5	SF

Asbestos Summary

Client: **William Paterson University**

Facility: **Hunziker Hall**

Project No.: **14-1532**

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
--------------	-----------------	--------------------	----------------------	---------------	--------------

First Floor

Hallway by Elevator

46 9" Brown Floor Tile/Mastic 5 SF

Hallway by Theatre

08 Ceiling Plaster 100 SF

Hallway outside Room 35

02 Pipe Insulation 100 LF

Hallways

05 Fire Door 200 SF

Janitor's Closet

21 9" Red Floor Tile/Mastic 120 SF

Janitor's Janitor's Closet

08 Ceiling Plaster 120 SF

Men's Restroom

08 Ceiling Plaster 200 SF

Room 105B

06 12" Spline Ceiling Tile 150 SF

26 12" Tan with Black Floor
Tile/Mastic 250 SF

Room 108 Performing Arts Series

08 Ceiling Plaster 400 SF

21 9" Red Floor Tile/Mastic 800 SF

Room 109

06 12" Spline Ceiling Tile 575 SF

Room 110

06 12" Spline Ceiling Tile 575 SF

Speech Clinic Bathroom

02 Pipe Insulation 75 LF

04 Fittings associated with
Fiberglass Pipe Insulation 10 LF

Stairwell by Theatre

02 Pipe Insulation 10 LF

Asbestos Summary

Client: William Paterson University

Facility: Hunziker Hall

Project No.: 14-1532

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
--------------	-----------------	--------------------	----------------------	---------------	--------------

First Floor

Stairwell by Theatre

08	Ceiling Plaster	320	SF
----	-----------------	-----	----

Storage Room next to Telecom Room

08	Ceiling Plaster	30	SF
----	-----------------	----	----

Storage Room Pipe Chase (near telecom room)

02	Pipe Insulation	30	LF
----	-----------------	----	----

Telecom Room

08	Ceiling Plaster	30	SF
----	-----------------	----	----

Theatre Exit

08	Ceiling Plaster	60	SF
----	-----------------	----	----

Theatre Hallway Vestibule

08	Ceiling Plaster	96	SF
----	-----------------	----	----

Theatre Kitchen

08	Ceiling Plaster	144	SF
----	-----------------	-----	----

Theatre Room 113

05	Fire Door	32	SF
----	-----------	----	----

08	Ceiling Plaster	65	SF
----	-----------------	----	----

Theatre Room 123

05	Fire Door	32	SF
----	-----------	----	----

08	Ceiling Plaster	65	SF
----	-----------------	----	----

Throughout

05	Fire Door	100	SF
----	-----------	-----	----

Throughout Classrooms

24	Glue Dots associated with Chalkboard	450	SF
----	--------------------------------------	-----	----

Utility Closet

02	Pipe Insulation	25	LF
----	-----------------	----	----

04	Fittings associated with Fiberglass Pipe Insulation	15	LF
----	---	----	----

Women's Restroom

08	Ceiling Plaster	200	SF
----	-----------------	-----	----

Asbestos Summary

Client: William Paterson University

Facility: Hunziker Hall

Project No.: 14-1532

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
Roof					
	<u>Elevator Penthouse</u>				
		39	Vibration Collar	15	SF
Second Floor					
	<u>200 Department of Women's Studies</u>				
		06	12" Spline Ceiling Tile	275	SF
		35	9" Gray Floor Tile/Mastic	200	SF
	<u>205 Women's Gender Studies</u>				
		06	12" Spline Ceiling Tile	525	SF
		08	Ceiling Plaster	525	SF
	<u>210 Women's and Gender Studies Department</u>				
		06	12" Spline Ceiling Tile	525	SF
	<u>Classroom 201</u>				
		06	12" Spline Ceiling Tile	950	SF
	<u>Exterior</u>				
		42	Exterior Window Caulk	350	LF
	<u>Hallway</u>				
		06	12" Spline Ceiling Tile	2,500	SF
		47	Dumb Waiter Access Door	5	SF
	<u>Hallway by Elevator</u>				
		46	9" Brown Floor Tile/Mastic	5	SF
	<u>Hallways</u>				
		05	Fire Door	200	SF
	<u>Room 202</u>				
		06	12" Spline Ceiling Tile	750	SF
	<u>Room 203</u>				
		06	12" Spline Ceiling Tile	1,125	SF
	<u>Room 203A</u>				
		21	9" Red Floor Tile/Mastic	500	SF
	<u>Room 204</u>				

Asbestos Summary

Client: **William Paterson University**

Facility: **Hunziker Hall**

Project No.: **14-1532**

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
--------------	-----------------	--------------------	----------------------	---------------	--------------

Second Floor

Room 204

06	12" Spline Ceiling Tile	80	SF
----	-------------------------	----	----

Room 205

06	12" Spline Ceiling Tile	625	SF
----	-------------------------	-----	----

Room 205A

35	9" Gray Floor Tile/Mastic	600	SF
----	---------------------------	-----	----

Room 206

06	12" Spline Ceiling Tile	625	SF
----	-------------------------	-----	----

Room 207

06	12" Spline Ceiling Tile	625	SF
----	-------------------------	-----	----

Room 208

06	12" Spline Ceiling Tile	625	SF
----	-------------------------	-----	----

Room 209

06	12" Spline Ceiling Tile	525	SF
----	-------------------------	-----	----

Room 210

35	9" Gray Floor Tile/Mastic	245	SF
----	---------------------------	-----	----

Stairwell by Child Development Center

08	Ceiling Plaster	425	SF
----	-----------------	-----	----

Throughout

05	Fire Door	100	SF
----	-----------	-----	----

Throughout Classrooms

24	Glue Dots associated with Chalkboard	450	SF
----	--------------------------------------	-----	----

Utility Closet 134

04	Fittings associated with Fiberglass Pipe Insulation	5	LF
----	---	---	----

Waiting Area

02	Pipe Insulation	100	LF
----	-----------------	-----	----

Women's Restroom

06	12" Spline Ceiling Tile	65	SF
----	-------------------------	----	----

08	Ceiling Plaster	200	SF
----	-----------------	-----	----

Asbestos Summary

Client:	William Paterson University
Facility:	Hunziker Hall
Project No.:	14-1532

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
--------------	-----------------	--------------------	----------------------	---------------	--------------

Tower

Office

06	12" Spline Ceiling Tile	175	SF
21	9" Red Floor Tile/Mastic	100	SF
41	9" Tan with Black Floor Tile/Mastic	200	SF

Stairwell

08	Ceiling Plaster	100	SF
----	-----------------	-----	----



Appendix C

Material Reports and Analytical Data

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No:	01	<i>Material Contains >1% Asbestos: No</i>
Material Name:	Interior Window Glazing	
Type of Material:	Miscellaneous	

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Basement			
	Boiler Room	100	LF
	<i>Total</i>	100	LF

Sampling Data		
<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
01 – 01	2/24/2015	Boiler Room
01 – 02	2/24/2015	Boiler Room

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 02
Material Name: Pipe Insulation
Type of Material: Thermal

*Material Contains >1%
Asbestos:
Yes (prev. sampled)*

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Basement			
	Bathroom by Elevator	50	LF
	Costume Shop	100	LF
	Crawlspace	1,175	LF
	Elevator Room	200	LF
	Hallway	205	LF
	Hallway by Crawlspace Entrance	95	LF
	Party Closet Club 29	100	LF
	Room 139	100	LF
	Room 23	100	LF
	Storage	195	LF
	Storage outside Bathroom by Elevator Room	130	LF
First Floor			
	Bathroom across from Room 35	200	LF
	Child Development Center	100	LF
	Hallway outside Room 35	100	LF
	Speech Clinic Bathroom	75	LF
	Stairwell by Theatre	10	LF
	Storage Room Pipe Chase (near telecom room)	30	LF
	Utility Closet	25	LF
Second Floor			
	Waiting Area	100	LF
Total		3,090	LF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 04

Material Name: Fittings associated with Fiberglass
Pipe Insulation

Type of Material: Thermal

*Material Contains >1%
Asbestos:
Yes (prev. sampled)*

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>Basement</i>			
	Throughout	60	LF
<i>First Floor</i>			
	Speech Clinic Bathroom	10	LF
	Utility Closet	15	LF
<i>Second Floor</i>			
	Utility Closet 134	5	LF
<i>Total</i>		90	LF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 05

Material Name: Fire Door

Type of Material: Thermal

*Material Contains >1%
Asbestos:
Yes (assumed)*

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>Basement</i>			
	Boiler Room	115	SF
	Hallways	120	SF
	Throughout	100	SF
<i>First Floor</i>			
	Hallways	200	SF
	Theatre Room 113	32	SF
	Theatre Room 123	32	SF
	Throughout	100	SF
<i>Second Floor</i>			
	Hallways	200	SF
	Throughout	100	SF
<i>Total</i>		999	SF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 06
Material Name: 12" Spline Ceiling Tile
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:
No (prev. sampled)*

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Basement			
	Hallway	240	SF
First Floor			
	100 American Federation of Teacher's	500	SF
	104 UPA Executive Director	180	SF
	105A UPA Conference Room	250	SF
	Hallway	2,500	SF
	Room 105B	150	SF
	Room 109	575	SF
	Room 110	575	SF
Second Floor			
	200 Department of Women's Studies	275	SF
	205 Women's Gender Studies	525	SF
	210 Women's and Gender Studies Department	525	SF
	Classroom 201	950	SF
	Hallway	2,500	SF
	Room 202	750	SF
	Room 203	1,125	SF
	Room 204	80	SF
	Room 205	625	SF
	Room 206	625	SF
	Room 207	625	SF
	Room 208	625	SF
	Room 209	525	SF
	Women's Restroom	65	SF
Tower			
	Office	175	SF
Total		14,965	SF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 08
Material Name: Ceiling Plaster
Type of Material: Surfacing

*Material Contains >1%
Asbestos:
No (prev. sampled)*

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Basement			
	Hallway by Crawlspace Entrance	350	SF
	Storage	400	SF
First Floor			
	Hallway by Theatre	100	SF
	Janitor's Janitor's Closet	120	SF
	Men's Restroom	200	SF
	Room 108 Performing Arts Series	400	SF
	Stairwell by Theatre	320	SF
	Storage Room next to Telecom Room	30	SF
	Telecom Room	30	SF
	Theatre Exit	60	SF
	Theatre Hallway Vestibule	96	SF
	Theatre Kitchen	144	SF
	Theatre Room 113	65	SF
	Theatre Room 123	65	SF
	Women's Restroom	200	SF
Second Floor			
	205 Women's Gender Studies	525	SF
	Stairwell by Child Development Center	425	SF
	Women's Restroom	200	SF
Tower			
	Stairwell	100	SF
Total		3,830	SF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 09
Material Name: Drywall
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Basement			
	Hallway by Crawlspace Entrance	400	SF
	Storage	320	SF
First Floor			
	104 UPA Executive Director	220	SF
	105A UPA Conference Room	320	SF
	133 Office of General Education	600	SF
	Adjunct Office 132	600	SF
	Hallway by Room 130	450	SF
	Room 105B	320	SF
	Room 128	650	SF
	Room 130	600	SF
	Room 131	525	SF
	Theatre	600	SF
	Women's Restroom	200	SF
Second Floor			
	205A Women's Gender Studies	425	SF
	Office Area/Department of Health 136	650	SF
Total		6,880	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
09 – 03	2/24/2015	Room 110
09 – 04	2/24/2015	Theatre Stage

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 10
Material Name: Joint Compound
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Basement			
	Hallway by Crawlspace Entrance	30	SF
	Storage	30	SF
First Floor			
	104 UPA Executive Director	25	SF
	105A UPA Conference Room	25	SF
	133 Office of General Education	45	SF
	Adjunct Office 132	45	SF
	Hallway by Room 130	50	SF
	Room 105B	25	SF
	Room 128	55	SF
	Room 130	45	SF
	Room 131	525	SF
	Theatre	40	SF
	Women's Restroom	25	SF
Second Floor			
	205A Women's Gender Studies	35	SF
	Office Area/Department of Health 136	60	SF
Total		1,060	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
10 – 05	2/24/2015	Room 110
10 – 06	2/24/2015	Theatre Stage

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 11
Material Name: Ceramic Tile Grout
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Basement			
	Throughout	200	SF
First Floor			
	Throughout	3,600	SF
Second Floor			
	Throughout	3,600	SF
Total		7,400	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
11 07	2/24/2015	Ground Floor Hallway
11 - 08	2/24/2015	Ground Floor Hallway

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 12
Material Name: Window Sill Slate
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Throughout	625	SF
Second Floor			
	Throughout	625	SF
Total		1,250	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
12 - 09	2/24/2015	Conference Room
12 - 10	2/24/2015	Room #4 Dressing

Material Report

Client: William Paterson University

Facility: Hunziker Hall

Date: 2/24/2015

Project No: 14-1532

Homogeneous No: 13
Material Name: Wall Plaster
Type of Material: Surfacing

Material Contains >1%
Asbestos:
No

Level	Location	Amount	Units
First Floor			
	100 American Federation of Teacher's	800	SF
	104 UPA Executive Director	385	SF
	105A UPA Conference Room	100	SF
	133 Office of General Education	375	SF
	Adjunct Office 132	375	SF
	Bathroom across from Room 35	350	SF
	Child Development Center	350	SF
	Hallway	3,600	SF
	Janitor's Closet	385	SF
	Office 127	480	SF
	Room 105B	300	SF
	Room 108 Performing Arts Series	640	SF
	Room 109	800	SF
	Room 110	800	SF
	Room 128	600	SF
	Room 130	800	SF
	Room 131	800	SF
	Storage Room next to Telecom Room	160	SF
	Telecom Room	160	SF
	Theatre	800	SF
	Theatre Exit	200	SF
	Theatre Hallway	320	SF
	Theatre Hallway Vestibule	225	SF
	Theatre Kitchen	275	SF
	Theatre Room 113	250	SF
	Theatre Room 123	250	SF
	Women's Restroom	400	SF
Second Floor			
	200 Department of Women's Studies	425	SF
	205A Women's Gender Studies	425	SF
	Hallway	3,600	SF

Material Report

Client: William Paterson University

Facility: Hunziker Hall

Date: 2/24/2015

Project No: 14-1532

Homogeneous No: 13
Material Name: Wall Plaster
Type of Material: Surfacing

Material Contains >1%
Asbestos:
No

Level	Location	Amount	Units
	Office Area/Department of Health 136	800	SF
	Room 201	1,200	SF
	Room 202	1,600	SF
	Room 203	1,600	SF
	Room 205	800	SF
	Room 206	800	SF
	Room 207	800	SF
	Room 208	800	SF
	Room 209	800	SF
	Room 210 Women's and Gender Studies Department	425	SF
	Women's Restroom	320	SF
Tower			
	Office	425	SF
	Total	29,800	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
13 - 11	2/24/2015	Room 204
13 - 12	2/24/2015	Room 200
13 - 13	2/24/2015	Conference Room

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 14
Material Name: 2'x2' Lay-in Ceiling Tile
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	104 UPA Executive Director	180	SF
	105A UPA Conference Room	250	SF
	133 Office of General Education	425	SF
	Adjunct Office 132	425	SF
	Bathroom across from Room 35	200	SF
	Child Development Center	110	SF
	Hallway by Room 128	300	SF
	Hallway by Room 130	300	SF
	Office 127	120	SF
	Room 105B	250	SF
	Room 128	625	SF
	Room 130	480	SF
	Room 131	500	SF
	Theatre	120	SF
	Theatre Exit	60	SF
	Theatre Hallway Vestibule	95	SF
	Theatre Room 123	65	SF
	Total	4,505	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
14 – 14	2/24/2015	Theatre Hallway
14 – 15	2/24/2015	Conference Room

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 15
Material Name: 12" Green Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Theatre Hallway	100	SF
	Theatre Room 123	80	SF
	Total	180	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
15 – 16	2/24/2015	Theatre Hall
15 – 17	2/24/2015	Theatre Room 123

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 16
Material Name: Black Cove Base Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Janitor's Closet	40	LF
	Room 105B	40	LF
	Room 108 Performing Arts Series	125	LF
	Storage Room next to Telecom Room	25	LF
	Theatre Hallway	40	LF
	Theatre Kitchen	50	LF
	Theatre Room 113	40	LF
	Theatre Room 123	40	LF
Second Floor			
	Office Area/Department of Health 136	84	LF
	Room 210 Women's and Gender Studies Department	40	LF
Total		524	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
16 – 18	2/24/2015	Room 105B
16 – 19	2/24/2015	Theatre

Material Report

Client: William Paterson University

Facility: Hunziker Hall

Date: 2/24/2015

Project No: 14-1532

Homogeneous No: 17
Material Name: 12" Gray and Green Floor
Tile/Mastic
Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Theatre Kitchen	144	SF
	Theatre Room 113	65	SF
	Total	209	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
17 – 20	2/24/2015	Room 113
17 – 21	2/24/2015	Kitchen behind Stage

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 18
Material Name: 12" Brown Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Theatre Exit	60	SF
	<i>Total</i>	60	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
18 – 22	2/24/2015	Theatre Exit Vestibule
18 23	2/24/2015	Theatre Exit Vestibule

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 19
Material Name: 12" Beige Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Room 201	325	LF
	Theatre Hallway Vestibule	95	SF
	Total	420	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
19 – 24	2/24/2015	Theatre Hallway Vestibule
19 – 25	2/24/2015	Theatre Hallway Vestibule

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 20
Material Name: Brown Cove Base Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Room 109	60	LF
	Room 110	60	LF
	Theatre Hallway Vestibule	30	SF
Second Floor			
	200 Department of Women's Studies	60	LF
	Room 201	120	LF
	Room 202	120	LF
	Room 203	120	LF
	Room 204	120	LF
	Room 205	120	LF
	Room 206	120	LF
	Room 207	120	LF
	Room 208	120	LF
Tower			
	Office	40	LF
Total		1,210	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
20 – 26	2/24/2015	Theatre Hallway Vestibule
20 – 27	2/24/2015	Classroom 201

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 21
Material Name: 9" Red Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:
Yes (assumed)*

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>First Floor</i>			
	Janitor's Closet	120	SF
	Room 108 Performing Arts Series	800	SF
<i>Second Floor</i>			
	Room 203A	500	SF
<i>Tower</i>			
	Office	100	SF
<i>Total</i>		1,520	SF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 22
Material Name: 12" Black Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Storage Room next to Telecom Room	60	SF
	<i>Total</i>	60	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
22 – 28	2/24/2015	Storage Room next to Telecom Room
22 – 29	2/24/2015	Storage Room next to Telecom Room

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 23
Material Name: 12" Tan Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Room 109	800	SF
	Room 110	800	SF
	Women's Restroom	40	SF
Second Floor			
	Room 201	625	SF
Total		2,265	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
23 30	2/24/2015	Room 109
23 - 31	2/24/2015	Ladies Room Hallway

Material Report

Client: William Paterson University

Facility: Hunziker Hall

Date: 2/24/2015

Project No: 14-1532

Homogeneous No: 24

Material Name: Glue Dots associated with Chalkboard

Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:
Yes (assumed)*

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Throughout Classrooms	450	SF
Second Floor			
	Throughout Classrooms	450	SF
	Total	900	SF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 25
Material Name: 12" Beige with Brown Floor
Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
Yes

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Elevator	35	SF
	<i>Total</i>	35	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
25 32	2/24/2015	Elevator
25 - 33	2/24/2015	Elevator

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 26
Material Name: 12" Tan with Black Floor
Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
Yes

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>First Floor</i>			
	104 UPA Executive Director	180	SF
	105A UPA Conference Room	250	SF
	Room 105B	250	SF
	<i>Total</i>	680	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
26 – 34	2/24/2015	Room 104B
26 – 35	2/24/2015	Room 104B

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 27
Material Name: Burgundy Cove Base Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	104 UPA Executive Director	40	LF
	105A UPA Conference Room	40	LF
	<i>Total</i>	80	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
27 - 36	2/24/2015	Room 105A
27 - 37	2/24/2015	Room 104

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 28
Material Name: 12" White and Black Floor
Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>First Floor</i>			
	133 Office of General Education	425	SF
	Adjunct Office 132	425	SF
	Hallway by Room 128	300	SF
	Hallway by Room 130	300	SF
	Office 127	120	SF
	Room 128	625	SF
	Room 130	480	SF
	Room 131	500	SF
	<i>Total</i>	3,175	SF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 29
Material Name: Grey Cove Base Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>First Floor</i>			
	133 Office of General Education	60	LF
	Adjunct Office 132	60	LF
	Hallway by Room 130	40	LF
	Office 127	40	LF
	Room 128	80	LF
	Room 130	80	LF
	Room 131	80	LF
	<i>Total</i>	440	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
29 - 38	2/24/2015	Room 128
29 - 39	2/24/2015	Room 131

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 31
Material Name: Brown Duct Insulation
Type of Material: Thermal

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Utility Closet	100	SF
Second Floor			
	Utility Closet 134	100	SF
Total		200	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
31 – 40	2/24/2015	Utility Closet 134
31 – 41	2/24/2015	Utility Closet by Day Care

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 34
Material Name: Fiber Board (Behind Radiators)
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Throughout (behind unit ventilators)	200	SF
Second Floor			
	Throughout (behind unit ventilators)	200	SF
Total		400	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
34 – 42	2/24/2015	Conference Room
34 – 43	2/24/2015	Room 202

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No:	35	<i>Material Contains >1% Asbestos: Yes (assumed)</i>
Material Name:	9" Gray Floor Tile/Mastic	
Type of Material:	Miscellaneous	

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Second Floor			
	200 Department of Women's Studies	200	SF
	Room 205A	600	SF
	Room 210	245	SF
	<i>Total</i>	1,045	SF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 36
Material Name: 12" Multi-color Beige Floor
Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Second Floor			
	Room 202	750	SF
	Room 203	750	SF
	Room 205	625	SF
	Room 207	625	SF
	Room 208	625	SF
	Room 209	625	SF
	Women's Restroom	65	SF
	<i>Total</i>	4,065	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
36 – 44	2/24/2015	Room 202
36 – 45	2/24/2015	Room 205

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 37
Material Name: 12" Pink Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Second Floor			
	Room 202	125	SF
	<i>Total</i>	125	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
37 – 46	2/24/2015	Room 203
37 47	2/24/2015	Room 203

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 38
Material Name: 12" Light Beige Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Second Floor			
	Room 206	625	SF
	<i>Total</i>	625	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
38 – 48	2/24/2015	Room 206
38 49	2/24/2015	Room 206

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No:	39	<i>Material Contains >1% Asbestos: Yes (assumed)</i>
Material Name:	Vibration Collar	
Type of Material:	Miscellaneous	

Level	Location	Amount	Units
Roof	Elevator Penthouse	15	SF
Total		15	SF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 40
Material Name: 2'x4' Lay-in Ceiling Tile
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Second Floor			
	Office Area/Department of Health 136	305	SF
	<i>Total</i>	305	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
40 – 50	2/24/2015	Department of Health Office Area
40 51	2/24/2015	Department of Health Office Area

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No:	41	<i>Material Contains >1% Asbestos: Yes (assumed)</i>
Material Name:	9" Tan with Black Floor Tile/Mastic	
Type of Material:	Miscellaneous	

Level	Location	Amount	Units
Tower			
	Office	200	SF
	Total	200	SF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 42
Material Name: Exterior Window Caulk
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
Yes

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Exterior	350	LF
Second Floor			
	Exterior	350	LF
Total		700	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
42 – 52	2/24/2015	Exterior
42 – 53	2/24/2015	Exterior

Material Report

Client: William Paterson University

Facility: Hunziker Hall

Date: 2/24/2015

Project No: 14-1532

Homogeneous No: 43

Material Name: Exterior Boiler Room Window
Glazing

Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Basement			
	Exterior Boiler Room	100	LF
	<i>Total</i>	100	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
43 - 54	2/24/2015	Exterior (Boiler Room)
43 - 55	2/24/2015	Exterior (Boiler Room)

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 44
Material Name: Exterior Brick Mortar
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Exterior	2,800	SF
Second Floor			
	Exterior	2,800	SF
Total		5,600	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
44 – 56	2/24/2015	Exterior
44 – 57	2/24/2015	Exterior

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 45
Material Name: Exterior Boiler Room Window Caulk
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
Yes

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Basement			
	Exterior Boiler Room	60	LF
	<i>Total</i>	60	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
45 - 58	2/24/2015	Exterior (Boiler Room)
45 - 59	2/24/2015	Exterior (Boiler Room)

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No:	46	<i>Material Contains >1% Asbestos: Yes</i>
Material Name:	9" Brown Floor Tile/Mastic	
Type of Material:	Miscellaneous	

Level	Location	Amount	Units
First Floor			
	Hallway by Elevator	5	SF
Second Floor			
	Hallway by Elevator	5	SF
Total		10	SF

Material Report

Client: William Paterson University
Facility: Hunziker Hall
Date: 2/24/2015
Project No: 14-1532

Homogeneous No: 47
Material Name: Dumb Waiter Access Door
Type of Material: Thermal

*Material Contains >1%
Asbestos:
Yes (assumed)*

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>Basement</i>			
	Mechanical Room	5	SF
<i>First Floor</i>			
	Hallway	5	SF
<i>Second Floor</i>			
	Hallway	5	SF
<i>Total</i>		15	SF



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

P.O. 016993 E-MAIL ALL RESULTS AND COC TO: ih-lablab@ttienv.com

PLM Sampling Data and Chain of Custody Record

PROJECT #: 14-1578	CLIENT: William Peterson	Univ.	TTI PROJECT MANAGER: Ox Jim Guillard O Michael Stocku	JS
SAMPLER(S): J.S.	CLIENT CONTACT: P.S.	FACILITY: Hunziker Hall	DATE: 12/30/15	
Sample #	Sample Location	Material Description	Sample Container	
01-01	Boiler Room	Interior window Glazing	Whirl Pak	
01-02	Boiler Room	Interior window Glazing		
05-03	Room 110	Drywall		
09-04	Theater Stage	Drywall		
10-05	Room 110	Joint Compound		
10-06	Theater Stage	Joint Compound		
11-07	Hallway	Ceramic Tile Grout		
11-08	Hallway	Ceramic Tile Grout		
12-09	Conference Room	window slate		
12-10	Room #4 Dressing	window slate		
13-11	Room 204	wall plaster		
13-12	Room 200	wall plaster		
13-13	Conference Room	wall plaster		
14-14	Theatre Hallway	2x2 lay-in ceiling Tile		
14-15	Conference Room	2x2 lay-in ceiling Tile		
15-16	Theatre Hall	12" green F.T./mastic		
15-17	Theatre Room 123	12" green F.T./mastic		
16-18	Room 10513	Black lac base mastic		
Relinquished by: (Signature)	Date: 2/14/15	Received by: (Signature)	Time	Date
Relinquished by: (Signature)	Date	Received by: (Signature)	Time	Date
NOB MATERIALS: Perform TEM analysis of 1st sample in each homogeneous group. (Initials)		Stop At First Positive		

RECEIVED
CINNAMARSON, N.J.
2015 FEB 14 A 8:31

51

DNB-2

830A

2-14-15



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

04/15/2004

E-MAIL ALL RESULTS AND COC TO: ih-lab@ttienvironment.com

OrderID: 041504204

PLM Sampling Data and Chain of Custody Record

PROJECT #: 14-1578		CLIENT: William Patterson Univ.		TTI PROJECT MANAGER:		Ox Jim Guillard O Michael Stocku		J.S.	
SAMPLER(S): J.S.		CLIENT CONTACT:		FACILITY: Hunziker Hall		DATE: 12/30/13		Sample Container	
Sample #	Sample Location	Material Description							
16-19	Theatre	Black Cove base mastic						White 1 Dash	
17-20	Room 113	12" Grey/Green F.T./Mastic							
17-21	Kitchen behind stage	12" Grey/Green F.T./Mastic							
18-22	Theatre Exit vestibule	12" Brown F.T./Mastic							
18-23	Theatre Exit vestibule	12" Brown F.T./Mastic							
19-24	Theatre Hallway vestibule	12" Beige F.T./Mastic							
19-25	Theatre Hallway vestibule	12" Beige F.T./Mastic							
20-26	Theatre Hallway vestibule	Brown Cove base mastic							
20-27	Classroom 201	Brown Cove base mastic						2015 FEB 14	
22-28	Storage Room next Telecom RM	12" Black F.T./Mastic						RECEIVED CINNAMINSON, N.J.	
22-29	Storage Room next Telecom RM	12" Black F.T./Mastic						A 8:31	
23-30	Classroom 109	12" Tan F.T./Mastic							
23-31	Ladies RM Hallway	12" Tan F.T./Mastic							
25-32	Elevator	12" Beige w/ Brown F.T./Mastic							
25-33	Elevator	12" Beige w/ Brown F.T./Mastic							
26-34	Room 104 B	12" Tan w/ Black F.T./Mastic							
26-35	Room 104 B	12" Tan w/ Black F.T./Mastic							
27-36	Room 105 A	Burgundy - Cove base mastic						↓	
Relinquished by: (Signature)		Date	Time	Received by: (Signature)	Date	Time	PO No.	Hour Turnaround Time	Stop At First Positive
Relinquished by: (Signature)		Date	Time	Received by: (Signature)	Date	Time	NOB MATERIALS: Perform TEM analysis of 1 st sample in each homogeneous group. (Initials)		
							For NOB samples with insufficient material for TEM analysis, please perform composite analysis using material from other samples in the same homogeneous group. (Initials)		



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

E-MAIL ALL RESULTS AND COC TO: ih-lablab@ttienv.com

PLM Sampling Data and Chain of Custody Record

PROJECT #: 14-1578	CLIENT: William Peterson Univ.	TTI PROJECT MANAGER: Ox Jim Guillard O Michael Stocku	DATE: 12/30/14
SAMPLER(S): J.S.	CLIENT CONTACT:	FACILITY: Hentziker Hall	Sample Container
Sample #	Sample Location	Material Description	Sample Container
27-37	Room 1034	Burgundy Cove base mastic	Whirl Pak
29-38	Room 128	Gray Cove base mastic	
29-39	Room 131	Gray Cove base mastic	
31-40	Utility Closet 134	Brown Duct Insulation	
31-41	Utility Closet by Day Care	Brown Duct Insulation	
34-42	Conference Room	Fiber Board material behind ventilators	
34-43	Classroom 202	Fiber Board material behind ventilators	
36-44	Room 202	12" Multi-Beige F.T./Mastic	
36-45	Room 205	12" Multi-Beige F.T./Mastic	
37-46	Room 203	12" Pink F.T./Mastic	
37-47	Room 203	12" Pink F.T./Mastic	
38-48	Room 206	12" Light Beige F.T./Mastic	
38-49	Room 206	12" Light Beige F.T./Mastic	
40-50	Dept. of Health Office Area	2x4 Lay-in ceiling tile	
40-51	Dept. of Health Office Area	2x4 Lay-in ceiling tile	
42-52	Exterior	Window - caulk	
42-53	Exterior	Window - caulk	
43-54	Exterior (Boiler Am)	Window Glazing	
Relinquished by: (Signature)	Date	Time	Received by: (Signature)
Relinquished by: (Signature)	Date	Time	Received by: (Signature)
PO No. _____		Hour Turnaround Time	Stop At First Positive
NOB MATERIALS: <input checked="" type="checkbox"/> Perform TEM analysis of 1 st sample in each homogeneous group. (Initials) _____ <input checked="" type="checkbox"/> For NOB samples with insufficient material for TEM analysis, please perform composite analysis using material from other samples in the same homogeneous group. (Initials) _____			

06/50204

1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815



PLM: Sampling Data and Chain of Custody Record

[illegible]



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504204
 Customer ID: TTIE54
 Customer PO: 016993
 Project ID: William Paterson Univ

Attn: Jim Guilardi
 TTI Environmental Inc.
 1253 North Church Street
 Moorestown, NJ 08057

Phone: (856) 840-8800
Fax: (856) 840-8815
Collected: 12/30/2014
Received: 2/14/2015
Analyzed: 2/25/2015

Proj: 14-1578 / Hunziker Hall (William Paterson Univ)

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 01-01 **Lab Sample ID:** 041504204-0001

Sample Description: Boiler Room/Interior Window Glazing

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Gray	0.0%	100%	None Detected	

Client Sample ID: 01-02 **Lab Sample ID:** 041504204-0002

Sample Description: Boiler Room/Interior Window Glazing

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray	0%	100%	None Detected	

Client Sample ID: 09-03 **Lab Sample ID:** 041504204-0003

Sample Description: Room 110/Drywall

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Brown/Gray	10%	90%	None Detected	

Client Sample ID: 09-04 **Lab Sample ID:** 041504204-0004

Sample Description: Theater Stage/Drywall

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Brown/Gray	15%	85%	None Detected	

Client Sample ID: 10-05 **Lab Sample ID:** 041504204-0005

Sample Description: Room 110/Joint Compound

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	White	0%	100%	None Detected	

Client Sample ID: 10-06 **Lab Sample ID:** 041504204-0006

Sample Description: Theater Stage/Joint Compound

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	White	0%	100%	None Detected	

Client Sample ID: 11-07 **Lab Sample ID:** 041504204-0007

Sample Description: Hallway/Ceramic Tile Grout

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray/White	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnaslab@EMSL.com

EMSL Order ID: 041504204
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 11-08 Lab Sample ID: 041504204-0008

Sample Description: Hallway/Ceramic Tile Grout

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray/White	0%	100%	None Detected	

Client Sample ID: 12-09 Lab Sample ID: 041504204-0009

Sample Description: Conference Room/Window Slate

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray	0%	100%	None Detected	

Client Sample ID: 12-10 Lab Sample ID: 041504204-0010

Sample Description: Room #4 Dressing/Window Slate

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray	0%	100%	None Detected	

Client Sample ID: 13-11-Skim Coat Lab Sample ID: 041504204-0011

Sample Description: Room 204/Wall Plaster

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	White	0%	100%	None Detected	

Client Sample ID: 13-11-Base Coat Lab Sample ID: 041504204-0011A

Sample Description: Room 204/Wall Plaster

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray	0%	100%	None Detected	

Client Sample ID: 13-12-Skim Coat Lab Sample ID: 041504204-0012

Sample Description: Room 200/Wall Plaster

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	White	0%	100%	None Detected	

Client Sample ID: 13-12-Base Coat Lab Sample ID: 041504204-0012A

Sample Description: Room 200/Wall Plaster

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray	0%	100%	None Detected	

Client Sample ID: 13-13-Skim Coat Lab Sample ID: 041504204-0013

Sample Description: Conference Room/Wall Plaster

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	White	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504204
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 13-13-Base Coat **Lab Sample ID:** 041504204-0013A
Sample Description: Conference Room/Wall Plaster

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray	0%	100%	None Detected	

Client Sample ID: 14-14 **Lab Sample ID:** 041504204-0014
Sample Description: Theatre Hallway/2 x 2 Lay-In Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray/White	90%	10%	None Detected	

Client Sample ID: 14-15 **Lab Sample ID:** 041504204-0015
Sample Description: Conference Room/2 x 2 Lay-In Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray/White	90%	10%	None Detected	

Client Sample ID: 15-16-Floor Tile **Lab Sample ID:** 041504204-0016
Sample Description: Theatre Hall/12" Green F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Green	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Green	0.0%	100%	None Detected	

Client Sample ID: 15-16-Mastic **Lab Sample ID:** 041504204-0016A
Sample Description: Theatre Hall/12" Green F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Black	0.0%	100%	None Detected	

Client Sample ID: 15-17-Floor Tile **Lab Sample ID:** 041504204-0017
Sample Description: Theatre Rm. 123/12" Green F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Green	0%	100%	None Detected	

Client Sample ID: 15-17-Mastic **Lab Sample ID:** 041504204-0017A
Sample Description: Theatre Rm. 123/12" Green F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black	0%	100%	None Detected	

Client Sample ID: 16-18 **Lab Sample ID:** 041504204-0018
Sample Description: Rm. 105B/Black Covebase Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Brown	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Brown	0.0%	100%	<0.27% Chrysotile	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnaslab@EMSL.com

EMSL Order ID: 041504204
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 16-19 **Lab Sample ID:** 041504204-0019

Sample Description: Theatre/Black Covebase Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Brown	0%	100%	None Detected	

Client Sample ID: 17-20-Floor Tile **Lab Sample ID:** 041504204-0020

Sample Description: Room 113/12" Gray / Green F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Green	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Green	0.0%	100%	None Detected	

Client Sample ID: 17-20-Mastic **Lab Sample ID:** 041504204-0020A

Sample Description: Room 113/12" Gray / Green F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black/Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Black/Yellow	0.0%	100%	None Detected	

Client Sample ID: 17-21-Floor Tile **Lab Sample ID:** 041504204-0021

Sample Description: Kitchen Behind Stage/12" Gray / Green F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Green	0%	100%	None Detected	

Client Sample ID: 17-21-Mastic **Lab Sample ID:** 041504204-0021A

Sample Description: Kitchen Behind Stage/12" Gray / Green F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black/Yellow	0%	100%	None Detected	

Client Sample ID: 18-22-Floor Tile **Lab Sample ID:** 041504204-0022

Sample Description: Theatre Exit Vestibule/12" Brown F. T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Brown	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Brown	0.0%	100%	None Detected	

Client Sample ID: 18-22-Mastic **Lab Sample ID:** 041504204-0022A

Sample Description: Theatre Exit Vestibule/12" Brown F. T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Black	0.0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504204
 Customer ID: TTIE54
 Customer PO: 016993
 Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 18-23 Floor Tile **Lab Sample ID:** 041504204-0023

Sample Description: Theatre Exit Vestibule/12" Brown F. T./ Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Brown	0%	100%	None Detected	

Client Sample ID: 18-23-Mastic **Lab Sample ID:** 041504204-0023A

Sample Description: Theatre Exit Vestibule/12" Brown F. T./ Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Black	0%	100%	None Detected	

Client Sample ID: 19-24-Floor Tile **Lab Sample ID:** 041504204-0024

Sample Description: Theatre Hallway Vestibule/12" Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Beige	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Beige	0.0%	100%	None Detected	

Client Sample ID: 19-24-Mastic **Lab Sample ID:** 041504204-0024A

Sample Description: Theatre Hallway Vestibule/12" Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black/Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Black/Yellow	0.0%	100%	None Detected	

Client Sample ID: 19-25-Floor Tile **Lab Sample ID:** 041504204-0025

Sample Description: Theatre Hallway Vestibule/12" Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Beige	0%	100%	None Detected	

Client Sample ID: 19-25-Mastic **Lab Sample ID:** 041504204-0025A

Sample Description: Theatre Hallway Vestibule/12" Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Black/Yellow	0%	100%	None Detected	

Client Sample ID: 20-26 **Lab Sample ID:** 041504204-0026

Sample Description: Theatre Hallway Vestibule/Brown Covebase Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Brown	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Brown	0.0%	100%	None Detected	

Client Sample ID: 20-27 **Lab Sample ID:** 041504204-0027

Sample Description: Classroom 201/Brown Covebase Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Brown	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnaslab@EMSL.com

EMSL Order ID: 041504204
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 22-28 **Lab Sample ID:** 041504204-0028

Sample Description: Storage Room Next Telecom Rm./12" Black F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black	0%	100%	None Detected	No mastic present.

Client Sample ID: 22-29-Floor Tile **Lab Sample ID:** 041504204-0029

Sample Description: Storage Room Next Telecom Rm./12" Black F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Black	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Black	0.0%	100%	None Detected	

Client Sample ID: 22-29-Mastic **Lab Sample ID:** 041504204-0029A

Sample Description: Storage Room Next Telecom Rm./12" Black F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Black/Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015				Insufficient Material	

Client Sample ID: 23-30-Floor Tile **Lab Sample ID:** 041504204-0030

Sample Description: Classroom 109/12" Tan F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Tan	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Tan	0.0%	100%	None Detected	

Client Sample ID: 23-30-Mastic **Lab Sample ID:** 041504204-0030A

Sample Description: Classroom 109/12" Tan F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015				Insufficient Material	

Client Sample ID: 23-31-Floor Tile **Lab Sample ID:** 041504204-0031

Sample Description: Ladies Rm. Hallway/12" Tan F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Tan	0%	100%	None Detected	

Client Sample ID: 23-31-Mastic **Lab Sample ID:** 041504204-0031A

Sample Description: Ladies Rm. Hallway/12" Tan F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Black	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504204
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 25-32-Floor Tile **Lab Sample ID:** 041504204-0032
Sample Description: Elevator/12" Beige w/ Brown F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Beige	0%	97%	3% Chrysotile	

Client Sample ID: 25-32-Mastic **Lab Sample ID:** 041504204-0032A
Sample Description: Elevator/12" Beige w/ Brown F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015				Stop Positive (Not Analyzed)	
TEM Grav. Reduction	2/25/2015	Black	0.0%	100%	<0.29% Chrysotile	

Client Sample ID: 25-33-Floor Tile **Lab Sample ID:** 041504204-0033
Sample Description: Elevator/12" Beige w/ Brown F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015				Stop Positive (Not Analyzed)	

Client Sample ID: 25-33 Mastic **Lab Sample ID:** 041504204-0033A
Sample Description: Elevator/12" Beige w/ Brown F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015				Stop Positive (Not Analyzed)	

Client Sample ID: 26-34-Floor Tile **Lab Sample ID:** 041504204-0034
Sample Description: Room 104B/12" Tan w/ Black F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray/Tan	0%	94%	6% Chrysotile	

Client Sample ID: 26-34-Mastic **Lab Sample ID:** 041504204-0034A
Sample Description: Room 104B/12" Tan w/ Black F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015				Stop Positive (Not Analyzed)	
TEM Grav. Reduction	2/25/2015	Brown	0.0%	96.8%	3.2% Chrysotile	

Client Sample ID: 26-35-Floor Tile **Lab Sample ID:** 041504204-0035
Sample Description: Room 104B/12" Tan w/ Black F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015				Stop Positive (Not Analyzed)	

Client Sample ID: 26-35-Mastic **Lab Sample ID:** 041504204-0035A
Sample Description: Room 104B/12" Tan w/ Black F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015				Stop Positive (Not Analyzed)	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504204
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 27-36 Lab Sample ID: 041504204-0036

Sample Description: Room 105A/Burgundy Covebase Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Brown/Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Brown/Yellow	0.0%	100%	None Detected	

Client Sample ID: 27-37 Lab Sample ID: 041504204-0037

Sample Description: Room 104/Burgundy Covebase Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Brown/Yellow	0%	100%	None Detected	

Client Sample ID: 29-38 Lab Sample ID: 041504204-0038

Sample Description: Room 128/Gray Covebase Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	White	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	White	0.0%	100%	None Detected	

Client Sample ID: 29-39 Lab Sample ID: 041504204-0039

Sample Description: Room 131/Gray Covebase Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	White	0%	100%	None Detected	

Client Sample ID: 31-40 Lab Sample ID: 041504204-0040

Sample Description: Utility Closet 134/Brown Duct Insulation

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black	20%	80%	None Detected	

Client Sample ID: 31-41 Lab Sample ID: 041504204-0041

Sample Description: Utility Closet by Day Care/Brown Duct Insulation

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Black	20%	80%	None Detected	

Client Sample ID: 34-42 Lab Sample ID: 041504204-0042

Sample Description: Conference Room/Fiber Board Material Behind Ventilators

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Tan	80%	20%	None Detected	

Client Sample ID: 34-43 Lab Sample ID: 041504204-0043

Sample Description: Classroom 202/Fiber Board Material Behind Ventilators

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Tan	80%	20%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504204
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 36-44-Floor Tile **Lab Sample ID:** 041504204-0044

Sample Description: Room 202/12" Multi- Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Tan	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Tan	0.0%	100%	None Detected	

Client Sample ID: 36-44-Mastic

Lab Sample ID: 041504204-0044A

Sample Description: Room 202/12" Multi- Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Black	0.0%	99.9%	0.13% Chrysotile	

Client Sample ID: 36-45-Floor Tile

Lab Sample ID: 041504204-0045

Sample Description: Room 205/12" Multi- Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Tan	0%	100%	None Detected	

Client Sample ID: 36-45-Mastic

Lab Sample ID: 041504204-0045A

Sample Description: Room 205/12" Multi- Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Black	0%	100%	None Detected	

Client Sample ID: 37-46-Floor Tile

Lab Sample ID: 041504204-0046

Sample Description: Room 203/12" Pink F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Pink	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Pink	0.0%	100%	None Detected	

Client Sample ID: 37-46-Mastic

Lab Sample ID: 041504204-0046A

Sample Description: Room 203/12" Pink F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black/Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Black/Yellow	0.0%	100%	None Detected	

Client Sample ID: 37-47-Floor Tile

Lab Sample ID: 041504204-0047

Sample Description: Room 203/12" Pink F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Pink	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504204
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 37-47-Mastic Lab Sample ID: 041504204-0047A

Sample Description: Room 203/12" Pink F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Black/Yellow	0%	100%	None Detected	

Client Sample ID: 38-48-Floor Tile Lab Sample ID: 041504204-0048

Sample Description: Room 206/12" Light Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Beige	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Beige	0.0%	100%	None Detected	

Client Sample ID: 38-48-Mastic Lab Sample ID: 041504204-0048A

Sample Description: Room 206/12" Light Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black/Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Black/Yellow	0.0%	100%	None Detected	

Client Sample ID: 38-49-Floor Tile Lab Sample ID: 041504204-0049

Sample Description: Room 206/12" Light Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Beige	0%	100%	None Detected	

Client Sample ID: 38-49-Mastic Lab Sample ID: 041504204-0049A

Sample Description: Room 206/12" Light Beige F.T. / Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Black/Yellow	0%	100%	None Detected	

Client Sample ID: 40-50 Lab Sample ID: 041504204-0050

Sample Description: Dept. of Health Office Area/2 x 4 Lay-In Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray/White	90%	10%	None Detected	

Client Sample ID: 40-51 Lab Sample ID: 041504204-0051

Sample Description: Dept. of Health Office Area/2 x 4 Lay-In Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Gray/White	90%	10%	None Detected	

Client Sample ID: 42-52 Lab Sample ID: 041504204-0052

Sample Description: Exterior/Window Caulk

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Black	0%	96%	4% Chrysotile	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504204
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 42-53 **Lab Sample ID:** 041504204-0053

Sample Description: Exterior/Window Caulk

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015					Stop Positive (Not Analyzed)

Client Sample ID: 43-54 **Lab Sample ID:** 041504204-0054

Sample Description: Exterior (Boiler Rm.)/Window Glazing

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray/Tan	0%	100%	None Detected	
TEM Grav. Reduction	2/20/2015	Gray/Tan	0.0%	100%	<0.1% Anthophyllite	

Client Sample ID: 43-55 **Lab Sample ID:** 041504204-0055

Sample Description: Exterior (Boiler Rm.)/Window Glazing

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Gray/Tan	0%	100%	None Detected	

Client Sample ID: 44-56 **Lab Sample ID:** 041504204-0056

Sample Description: Exterior/Red Brick Mortar

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray	0%	100%	None Detected	

Client Sample ID: 44-57 **Lab Sample ID:** 041504204-0057

Sample Description: Exterior/Red Brick Mortar

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/19/2015	Gray	0%	100%	None Detected	

Client Sample ID: 45-58 **Lab Sample ID:** 041504204-0058

Sample Description: Exterior (Boiler Rm.)/Window Caulk

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015	Gray/Tan	0%	95%	5% Chrysotile	

Client Sample ID: 45-59 **Lab Sample ID:** 041504204-0059

Sample Description: Exterior (Boiler Rm.)/Window Caulk

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/18/2015					Stop Positive (Not Analyzed)



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID:	041504204
Customer ID:	TTIE54
Customer PO:	016993
Project ID:	William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Analyst(s):

Adam Gart	PLM (40)
Chris Little	TEM Grav. Reduction (2)
Nancy Stalter	PLM (35)
Ted Young	TEM Grav. Reduction (22)

Reviewed and approved by:



Benjamin Ellis, Laboratory Manager
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. This test report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. EMSL bears no responsibility for sample collection activities or analytical method limitations. The laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples. PLM alone is not consistently reliable in detecting asbestos in floor coverings and similar NOBs.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NVLAP Lab Code 101048-0, AIHA-LAP, LLC-IHLAP Lab 100194, NYS ELAP 10872, NJ DEP 03036

Initial report from: 02/19/2015 07:25:25



Appendix D

Non Asbestos Material Summary

Non Asbestos Summary

William Paterson University

Hunziker Hall

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
Basement				
	Boiler Room	01	Interior Window Glazing	100 LF
	Exterior Boiler Room	43	Exterior Boiler Room Window Glazing	100 LF
	Hallway by Crawlspace Entrance	09	Drywall	400 SF
		10	Joint Compound	30 SF
	Storage	09	Drywall	320 SF
		10	Joint Compound	30 SF
	Throughout	11	Ceramic Tile Grout	200 SF
First Floor				
	100 American Federation of Teacher's	13	Wall Plaster	800 SF
	104 UPA Executive Director	09	Drywall	220 SF
		10	Joint Compound	25 SF
		13	Wall Plaster	385 SF
		14	2'x2' Lay-in Ceiling Tile	180 SF
		27	Burgundy Cove Base Mastic	40 LF
	105A UPA Conference Room	09	Drywall	320 SF
		10	Joint Compound	25 SF
		13	Wall Plaster	100 SF
		14	2'x2' Lay-in Ceiling Tile	250 SF
		27	Burgundy Cove Base Mastic	40 LF
	133 Office of General Education	09	Drywall	600 SF
		10	Joint Compound	45 SF
		13	Wall Plaster	375 SF
		14	2'x2' Lay-in Ceiling Tile	425 SF

Non Asbestos Summary

William Paterson University

Hunziker Hall

Project No: 14-1532

Level	Location	Homogeneous No.	Material Name	Amount
	133 Office of General Education			
		28	12" White and Black Floor Tile/Mastic	425 SF
		29	Grey Cove Base Mastic	60 LF
	Adjunct Office 132			
		09	Drywall	600 SF
		10	Joint Compound	45 SF
		13	Wall Plaster	375 SF
		14	2'x2' Lay-in Ceiling Tile	425 SF
		28	12" White and Black Floor Tile/Mastic	425 SF
		29	Grey Cove Base Mastic	60 LF
	Bathroom across from Room 35			
		13	Wall Plaster	350 SF
		14	2'x2' Lay-in Ceiling Tile	200 SF
	Child Development Center			
		13	Wall Plaster	350 SF
		14	2'x2' Lay-in Ceiling Tile	110 SF
	Exterior			
		44	Exterior Brick Mortar	2,800 SF
	Hallway			
		13	Wall Plaster	3,600 SF
	Hallway by Room 128			
		14	2'x2' Lay-in Ceiling Tile	300 SF
		28	12" White and Black Floor Tile/Mastic	300 SF
	Hallway by Room 130			
		09	Drywall	450 SF
		10	Joint Compound	50 SF
		14	2'x2' Lay-in Ceiling Tile	300 SF
		28	12" White and Black Floor Tile/Mastic	300 SF
		29	Grey Cove Base Mastic	40 LF
	Janitor's Closet			
		13	Wall Plaster	385 SF
		16	Black Cove Base Mastic	40 LF

Non Asbestos Summary

William Paterson University

Hunziker Hall

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
	Office 127			
		13	Wall Plaster	480 SF
		14	2'x2' Lay-in Ceiling Tile	120 SF
		28	12" White and Black Floor Tile/Mastic	120 SF
		29	Grey Cove Base Mastic	40 LF
	Room 105B			
		09	Drywall	320 SF
		10	Joint Compound	25 SF
		13	Wall Plaster	300 SF
		14	2'x2' Lay-in Ceiling Tile	250 SF
		16	Black Cove Base Mastic	40 LF
	Room 108 Performing Arts Series			
		13	Wall Plaster	640 SF
		16	Black Cove Base Mastic	125 LF
	Room 109			
		13	Wall Plaster	800 SF
		20	Brown Cove Base Mastic	60 LF
		23	12" Tan Floor Tile/Mastic	800 SF
	Room 110			
		13	Wall Plaster	800 SF
		20	Brown Cove Base Mastic	60 LF
		23	12" Tan Floor Tile/Mastic	800 SF
	Room 128			
		09	Drywall	650 SF
		10	Joint Compound	55 SF
		13	Wall Plaster	600 SF
		14	2'x2' Lay-in Ceiling Tile	625 SF
		28	12" White and Black Floor Tile/Mastic	625 SF
		29	Grey Cove Base Mastic	80 LF
	Room 130			
		09	Drywall	600 SF
		10	Joint Compound	45 SF
		13	Wall Plaster	800 SF

Non Asbestos Summary

William Paterson University

Hunziker Hall

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
	Room 130			
		14	2'x2' Lay-in Ceiling Tile	480 SF
		28	12" White and Black Floor Tile/Mastic	480 SF
		29	Grey Cove Base Mastic	80 LF
	Room 131			
		09	Drywall	525 SF
		10	Joint Compound	525 SF
		13	Wall Plaster	800 SF
		14	2'x2' Lay-in Ceiling Tile	500 SF
		28	12" White and Black Floor Tile/Mastic	500 SF
		29	Grey Cove Base Mastic	80 LF
	Room 201			
		19	12" Beige Floor Tile/Mastic	325 LF
	Storage Room next to Telecom Room			
		13	Wall Plaster	160 SF
		16	Black Cove Base Mastic	25 LF
		22	12" Black Floor Tile/Mastic	60 SF
	Telecom Room			
		13	Wall Plaster	160 SF
	Theatre			
		09	Drywall	600 SF
		10	Joint Compound	40 SF
		13	Wall Plaster	800 SF
		14	2'x2' Lay-in Ceiling Tile	120 SF
	Theatre Exit			
		13	Wall Plaster	200 SF
		14	2'x2' Lay-in Ceiling Tile	60 SF
		18	12" Brown Floor Tile/Mastic	60 SF
	Theatre Hallway			
		13	Wall Plaster	320 SF
		15	12" Green Floor Tile/Mastic	100 SF
		16	Black Cove Base Mastic	40 LF
	Theatre Hallway Vestibule			

Non Asbestos Summary

William Paterson University

Hunziker Hall

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
	Theatre Hallway Vestibule			
		13	Wall Plaster	225 SF
		14	2'x2' Lay-in Ceiling Tile	95 SF
		19	12" Beige Floor Tile/Mastic	95 SF
		20	Brown Cove Base Mastic	30 SF
	Theatre Kitchen			
		13	Wall Plaster	275 SF
		16	Black Cove Base Mastic	50 LF
		17	12" Gray and Green Floor Tile/Mastic	144 SF
	Theatre Room 113			
		13	Wall Plaster	250 SF
		16	Black Cove Base Mastic	40 LF
		17	12" Gray and Green Floor Tile/Mastic	65 SF
	Theatre Room 123			
		13	Wall Plaster	250 SF
		14	2'x2' Lay-in Ceiling Tile	65 SF
		15	12" Green Floor Tile/Mastic	80 SF
		16	Black Cove Base Mastic	40 LF
	Throughout			
		11	Ceramic Tile Grout	3,600 SF
		12	Window Sill Slate	625 SF
	Throughout (behind unit ventilators)			
		34	Fiber Board (Behind Radiators)	200 SF
	Utility Closet			
		31	Brown Duct Insulation	100 SF
	Women's Restroom			
		09	Drywall	200 SF
		10	Joint Compound	25 SF
		13	Wall Plaster	400 SF
		23	12" Tan Floor Tile/Mastic	40 SF
Second Floor				
	200 Department of Women's Studies			
		13	Wall Plaster	425 SF

Non Asbestos Summary

William Paterson University

Hunziker Hall

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
	200 Department of Women's Studies			
		20	Brown Cove Base Mastic	60 LF
	205A Women's Gender Studies			
		09	Drywall	425 SF
		10	Joint Compound	35 SF
		13	Wall Plaster	425 SF
	Exterior			
		44	Exterior Brick Mortar	2,800 SF
	Hallway			
		13	Wall Plaster	3,600 SF
	Office Area/Department of Health 136			
		09	Drywall	650 SF
		10	Joint Compound	60 SF
		13	Wall Plaster	800 SF
		16	Black Cove Base Mastic	84 LF
		40	2'x4' Lay-in Ceiling Tile	305 SF
	Room 201			
		13	Wall Plaster	1,200 SF
		20	Brown Cove Base Mastic	120 LF
		23	12" Tan Floor Tile/Mastic	625 SF
	Room 202			
		13	Wall Plaster	1,600 SF
		20	Brown Cove Base Mastic	120 LF
		36	12" Multi-color Beige Floor Tile/Mastic	750 SF
		37	12" Pink Floor Tile/Mastic	125 SF
	Room 203			
		13	Wall Plaster	1,600 SF
		20	Brown Cove Base Mastic	120 LF
		36	12" Multi-color Beige Floor Tile/Mastic	750 SF
	Room 204			
		20	Brown Cove Base Mastic	120 LF
	Room 205			

Non Asbestos Summary

William Paterson University

Hunziker Hall

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
	Room 205			
		13	Wall Plaster	800 SF
		20	Brown Cove Base Mastic	120 LF
		36	12" Multi-color Beige Floor Tile/Mastic	625 SF
	Room 206			
		13	Wall Plaster	800 SF
		20	Brown Cove Base Mastic	120 LF
		38	12" Light Beige Floor Tile/Mastic	625 SF
	Room 207			
		13	Wall Plaster	800 SF
		20	Brown Cove Base Mastic	120 LF
		36	12" Multi-color Beige Floor Tile/Mastic	625 SF
	Room 208			
		13	Wall Plaster	800 SF
		20	Brown Cove Base Mastic	120 LF
		36	12" Multi-color Beige Floor Tile/Mastic	625 SF
	Room 209			
		13	Wall Plaster	800 SF
		36	12" Multi-color Beige Floor Tile/Mastic	625 SF
	Room 210 Women's and Gender Studies Department			
		13	Wall Plaster	425 SF
		16	Black Cove Base Mastic	40 LF
	Throughout			
		11	Ceramic Tile Grout	3,600 SF
		12	Window Sill Slate	625 SF
	Throughout (behind unit ventilators)			
		34	Fiber Board (Behind Radiators)	200 SF
	Utility Closet 134			
		31	Brown Duct Insulation	100 SF
	Women's Restroom			
		13	Wall Plaster	320 SF

Non Asbestos Summary

William Paterson University

Hunziker Hall

Project No: 14-1532

Level	Location	Homogeneous No.	Material Name	Amount
Tower	Women's Restroom	36	12" Multi-color Beige Floor Tile/Mastic	65 SF
	Office	13	Wall Plaster	425 SF
		20	Brown Cove Base Mastic	40 LF