



*A Service Disabled Veteran
Owned Small Business*

TTI Environmental Incorporated
1253 N. Church Street
Moorestown, New Jersey 08057
Tel: 856-840-8800
Fax: 856-840-8815

INSPECTION, SAMPLING AND ANALYSIS

of

Hunziker Wing

300 Pompton Road

Wayne, New Jersey

for

ASBESTOS-CONTAINING BUILDING MATERIAL

conducted at the request of

Mr. Rick Stomber

VP of Capital Planning, Design and Construction

William Paterson University

300 Pompton Road

Wayne, New Jersey

TTI Project No. 14-1532

September 14, 2015



Asbestos Inspection

William Paterson University

Hunziker Wing

TTI Project No. 14-1532

September 14, 2015

Page 2 of 6

TABLE OF CONTENTS

	<u>Page</u>
I. EXECUTIVE SUMMARY	3
II. INTRODUCTION	4
III. INSPECTION, SAMPLING AND ANALYSIS METHODOLOGY	5
A. Inspection Methodology	
B. Sampling and Analysis Methodology	

Appendix A: Homogenous Material ID List

Appendix B: Asbestos Summary

Appendix C: Material Reports and Analytical Data

Appendix D: Non Asbestos Material Summary



Asbestos Inspection

William Paterson University

Hunziker Wing

TTI Project No. 14-1532

September 14, 2015

Page 3 of 6


I. EXECUTIVE SUMMARY

TTI Environmental, Inc. (TTI) performed a non-destructive asbestos inspection throughout the Hunziker Wing on the campus of William Paterson University in Wayne, New Jersey. The inspection was conducted on December 30, 2014. During the inspection, suspect Asbestos-Containing Building Materials (ACBM) were sampled, assessed and quantified.

Laboratory analysis of the suspect materials revealed an asbestos content of greater than one percent (1%) in the following materials or the materials are assumed to contain asbestos:

Material
<ul style="list-style-type: none">• Pipe insulation• Fitting Insulation associated with Fiberglass Pipe Insulation• Tank Insulation• 9" Speckled Tan and Beige/Mastic• Transite Pipe (assumed to contain asbestos)• 12" Gray and White Floor Tile/Mastic• 9" Tan Floor Tile/Mastic• Transite Panels• Fire Doors (assumed to contain asbestos)• Cream Floor Tile• Exterior Window Caulk (second Layer)• Exterior Door Caulk

The homogeneous materials ID list and the complete Asbestos Summary including recommendations can be found in Appendices A and B to this report respectively. For complete information regarding location and sampling of these materials, see Appendix C to this report. In addition, Appendix D contains a summary of those materials determined not to contain asbestos.



Jeffrey Seaman
Project Manager



Asbestos Inspection

William Paterson University

Hunziker Wing

TTI Project No. 14-1532

September 14, 2015

Page 4 of 6

II. INTRODUCTION

TTI was requested by Mr. Richard Stomber, VP of Capital Planning, Design and Construction for William Paterson University to conduct an inspection throughout the Hunziker Wing on the campus of William Paterson University in Wayne, New Jersey. The purpose of the inspection was to locate, sample, and quantify ACBM throughout the site.

The inspection was performed by United States Environmental Protection Agency (USEPA) Accredited Building Inspector, Jeffrey Seaman (#ACC-0911-6-001) who conducted a detailed visual examination of the site for suspect ACBM. This included collecting bulk samples, as well as quantifying both friable and non-friable suspect material.

The results, assessments and conclusions stated in this report are factually representative of the conditions and circumstances we observed on the dates of our inspection. We cannot assume responsibility for any change in conditions or circumstances that occurred subsequent to our inspection.

Certain materials were sampled in a previous asbestos survey performed by Environmental Connections, Inc. (EC), dated September 1999. Where possible TTI utilized these sample results as part of their survey.



Asbestos Inspection

William Paterson University

Hunziker Wing

TTI Project No. 14-1532

September 14, 2015

Page 5 of 6

III. INSPECTION, SAMPLING AND ANALYSIS METHODOLOGY

A. Inspection

The inspection was conducted in accordance with the guidelines established by the Asbestos Hazard Emergency Response Act (AHERA), as set forth in 40 CFR Part 763 of October 30, 1987, and provides a framework for addressing asbestos in public and private schools. The AHERA guidelines represent the most up-to-date inspection and sampling protocol available and as such were utilized while inspecting and sampling.

The USEPA defines "Homogeneous Areas" as those areas of surfacing, thermal system insulation, or miscellaneous materials, which are uniform in color, texture, and assumed to be installed at the same time. The suspected ACBM has been categorized into homogeneous areas. This assigned ID number can be used for cross-referencing between each section of the report.

For the purposes of this inspection, suspect ACBM has been placed in three material categories: surfacing, thermal and miscellaneous.

Surfacing materials are those that are sprayed-on, troweled-on or otherwise applied to surfaces.

Thermal materials are those applied to heat pipes or other structural components to prevent heat loss or gain or prevent water condensation. Thermal materials are characterized by their form or composition. For example, block pipe insulation is preformed magnesia and/or fibrous material molded for piping and usually covered with a canvas jacket stitched at the seams. It can be identified as hard to the touch when the jacket is intact or white and fibrous when exposed by a breach in the jacket. Cardboard pipe insulation when exposed from its protective jacket consists of layers of brown or gray cardboard pressed together and is typically found on domestic cold water piping. Air-cell is corrugated gray cardboard in layers, usually preformed for the diameter of the pipe in 2 to 3 foot sections and may have a canvas jacket. The block type pipe insulation is typically used where a high coefficient of insulation is desired or required.

Pipe fitting insulation on pipe runs insulated with fiberglass and which contain asbestos are usually hand molded mud applied to the fitting and may have a canvas wrapping over the material. The newer non-asbestos pipe fitting insulation is typically fiberglass covered with a PVC jacket.



Asbestos Inspection

William Paterson University

Hunziker Wing

TTI Project No. 14-1532

September 14, 2015

Page 6 of 6

III. INSPECTION, SAMPLING AND ANALYSIS METHODOLOGY (Continued)

A. Inspection (continued)

Miscellaneous materials are interior building materials on structural components, structural members or fixtures such as floor and ceiling tiles and do not include surfacing material or thermal system insulation.

Please note that destructive or exploratory sampling methods were not employed during the survey. In addition, access was limited to certain areas; therefore, TTI made a prudent effort to identify all accessible asbestos material in the building. During the sampling of floor tile several areas contained multiple layers of tile. Since destructive sampling methods were not employed, in accordance with current USEPA guidelines, tile layers below the surface are assumed to contain asbestos.

Due to the limited access to the materials listed above, quantification of these materials was not conducted during this inspection.

B. Sampling and Analysis

The USEPA requires that bulk samples of suspect ACM be collected in a manner sufficient to determine whether this material is ACM. ACM is any building material, which contains more than 1% asbestos. Generally, for thermal system areas or miscellaneous areas, three (3) bulk samples randomly taken are required to determine that suspected material is not ACM. Suspect surfacing materials sprayed or troweled-on may require up to nine (9) bulk samples, depending on area size, to determine whether the material is ACM.

Samples were taken in sufficient quantity in each Homogeneous Area to reliably determine the presence of asbestos. Analysis of samples collected in conjunction with this report was conducted by the following methods:

- . EPA 600/R-93/116
- . Transmission Electron Microscopy (TEM) in accordance with ELAP 198.4, revised 1/11/2005 and EPA-600/R-93/116 Section 2.5



Appendix A

Homogenous Material ID List

List of Materials

William Paterson University

Hunziker Wing

Project No: 14-1532

<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Type of Material</i>	<i>Material Contains >1% Asbestos</i>
01	Pipe Insulation	Thermal	Yes (prev. sampled)
03	Transite Panel	Miscellaneous	Yes (prev. sampled)
04	12" Tan Floor Tile/Mastic	Miscellaneous	No
05	Black Cove Base Mastic	Miscellaneous	No
06	2'x2' Fissured Lay-in Ceiling Tile	Miscellaneous	No
07	12" Beige Floor Tile/Mastic	Miscellaneous	No
08	Glue Dots associated with Chalkboard	Miscellaneous	No
09	Slate Window Sill	Miscellaneous	No
10	Tank Insulation	Miscellaneous	Yes (prev. sampled)
11	Fittings associated with Fiberglass Pipe Insulation	Thermal	Yes (prev. sampled)
12	Drywall	Miscellaneous	No
13	Joint Compound	Miscellaneous	No
15	2'x4' Lay-in Ceiling Tile	Miscellaneous	No
16	2'x2' Textured Ceiling Tile	Miscellaneous	No
18	Brown Cove Base Mastic	Miscellaneous	No
19	12" Black and White Speckled Floor Tile/Mastic	Miscellaneous	No
20	Wall Plaster	Surfacing	No
23	Ceramic Tile Grout	Miscellaneous	No
24	12" Multi-color Speckled Floor Tile/Mastic	Miscellaneous	No
25	12" Black Floor Tile/Mastic	Miscellaneous	No
26	12" Tan with Grey Streaks Floor Tile/Mastic	Miscellaneous	No
27	12" Spline Ceiling Tile	Miscellaneous	No
28	Glue Dots associated with 12" Spline Ceiling Tile	Miscellaneous	No
29	12" Beige with Tan Streaks Floor Tile/Mastic	Miscellaneous	No
30	2'x2' Smooth White Lay-in Ceiling Tile	Miscellaneous	No
32	9" Tan and Beige Speckled Floor Tile/Mastic	Miscellaneous	Yes
33	Green Cove Base Mastic	Miscellaneous	No
34	9" Black Floor Tile/Mastic	Miscellaneous	No
35	Brown Duct Insulation	Thermal	No
36	Transite Pipe	Miscellaneous	Yes (assumed)
37	Gray Cove Base	Miscellaneous	No
38	12" Green with Black Specks Floor Tile/Mastic	Miscellaneous	No

List of Materials

William Paterson University

Hunziker Wing

Project No: 14-1532

<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Type of Material</i>	<i>Material Contains >1% Asbestos</i>
39	12" Tan with Black Specks Floor Tile/Mastic	Miscellaneous	No
40	Interior Brick Mortar	Miscellaneous	No
41	12" Gray and White Floor Tile/Mastic	Miscellaneous	Yes
42	12" Tan with Brown Streaks Floor Tile/Mastic	Miscellaneous	No
43	9" Tan Floor Tile/Mastic	Miscellaneous	Yes
44	Cream Floor Tile/Mastic	Miscellaneous	Yes
45	12" Light Green Floor Tile/Mastic	Miscellaneous	No
46	Exterior Window Caulk (Top Layer)	Miscellaneous	No
47	Exterior Window Caulk (Second Layer)	Miscellaneous	Yes
48	Exterior Door Caulk	Miscellaneous	Yes
49	Exterior Red Brick Mortar	Miscellaneous	No
50	Tan Brick Mortar	Miscellaneous	No
51	Fire Doors	Miscellaneous	Yes (assumed)



Appendix B

Asbestos Summary

Asbestos Summary

Client: **William Paterson University**

Facility: **Hunziker Wing**

Project No.: **14-1532**

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
--------------	-----------------	--------------------	----------------------	---------------	--------------

First Floor

Auditorium

11	Fittings associated with Fiberglass Pipe Insulation	80	LF
----	--	----	----

Conference Room 120

01	Pipe Insulation	20	LF
11	Fittings associated with Fiberglass Pipe Insulation	6	LF
32	9" Tan and Beige Speckled Floor Tile/Mastic	500	SF

Department of Nursing Main Office 106

01	Pipe Insulation	10	LF
----	-----------------	----	----

Exterior

47	Exterior Window Caulk (Second Layer)	800	SF
----	---	-----	----

Hallway

01	Pipe Insulation	1,000	LF
03	Transite Panel	140	SF

HW 125

11	Fittings associated with Fiberglass Pipe Insulation	8	LF
----	--	---	----

Learning 102

01	Pipe Insulation	200	LF
32	9" Tan and Beige Speckled Floor Tile/Mastic	780	SF

Room 103 Student Success Program

01	Pipe Insulation	20	LF
----	-----------------	----	----

Room 104

32	9" Tan and Beige Speckled Floor Tile/Mastic	20	SF
----	---	----	----

Room 107

01	Pipe Insulation	20	LF
32	9" Tan and Beige Speckled Floor Tile/Mastic	60	SF

Asbestos Summary

Client: **William Paterson University**

Facility: **Hunziker Wing**

Project No.: **14-1532**

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
--------------	-----------------	--------------------	----------------------	---------------	--------------

First Floor

Room 108

01	Pipe Insulation	20	LF
----	-----------------	----	----

Room 110

01	Pipe Insulation	20	LF
----	-----------------	----	----

Room 111

01	Pipe Insulation	18	LF
----	-----------------	----	----

Room 124

32	9" Tan and Beige Speckled Floor Tile/Mastic	255	SF
----	---	-----	----

Room 126

01	Pipe Insulation	12	LF
32	9" Tan and Beige Speckled Floor Tile/Mastic	225	SF

Room 128

01	Pipe Insulation	10	LF
----	-----------------	----	----

Room 130

11	Fittings associated with Fiberglass Pipe Insulation	2	LF
----	--	---	----

Throughout Rooms (under unit ventilators)

32	9" Tan and Beige Speckled Floor Tile/Mastic	600	SF
----	---	-----	----

Ground Floor

10A-G Therapy Suites

11	Fittings associated with Fiberglass Pipe Insulation	1	LF
----	--	---	----

11E Clinician's Room

01	Pipe Insulation	30	LF
----	-----------------	----	----

4A Speech and Hearing Science Laboratory

11	Fittings associated with Fiberglass Pipe Insulation	16	LF
----	--	----	----

5A-E Therapy Suites

11	Fittings associated with Fiberglass Pipe Insulation	5	LF
----	--	---	----

Asbestos Summary

Client: **William Paterson University**

Facility: **Hunziker Wing**

Project No.: **14-1532**

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
--------------	-----------------	--------------------	----------------------	---------------	--------------

Ground Floor

6A Language Facilitation Computer Lab

11	Fittings associated with Fiberglass Pipe Insulation	6	LF
----	--	---	----

7A-E Faculty Offices

11	Fittings associated with Fiberglass Pipe Insulation	6	LF
----	--	---	----

43	9" Tan Floor Tile/Mastic	520	SF
----	--------------------------	-----	----

Communication Disorder and Sciences

01	Pipe Insulation	60	LF
----	-----------------	----	----

Elevator

43	9" Tan Floor Tile/Mastic	35	SF
----	--------------------------	----	----

44	Cream Floor Tile/Mastic	35	SF
----	-------------------------	----	----

Exterior

47	Exterior Window Caulk (Second Layer)	800	SF
----	---	-----	----

48	Exterior Door Caulk	25	LF
----	---------------------	----	----

Hallway

01	Pipe Insulation	1,000	LF
----	-----------------	-------	----

03	Transite Panel	140	SF
----	----------------	-----	----

Mechanical Room

01	Pipe Insulation	250	SF
----	-----------------	-----	----

10	Tank Insulation	200	LF
----	-----------------	-----	----

11	Fittings associated with Fiberglass Pipe Insulation	70	LF
----	--	----	----

Room 16

01	Pipe Insulation	10	LF
----	-----------------	----	----

Room 9 Observation Room

43	9" Tan Floor Tile/Mastic	150	SF
----	--------------------------	-----	----

Room outside Janitorial Supply

11	Fittings associated with Fiberglass Pipe Insulation	3	LF
----	--	---	----

Rooms 6C/6D

11	Fittings associated with Fiberglass Pipe Insulation	15	LF
----	--	----	----

Asbestos Summary

Client: William Paterson University

Facility: Hunziker Wing

Project No.: 14-1532

<u>Level</u>	<u>Location</u>	<u>Hom No.</u>	<u>Material Name</u>	<u>Amount</u>	<u>Units</u>
--------------	-----------------	--------------------	----------------------	---------------	--------------

Ground Floor

Rooms 6C/6D

43	9" Tan Floor Tile/Mastic	300	SF
----	--------------------------	-----	----

Server Room

01	Pipe Insulation	30	LF
----	-----------------	----	----

11	Fittings associated with Fiberglass Pipe Insulation	15	LF
----	--	----	----

41	12" Gray and White Floor Tile/Mastic	250	SF
----	---	-----	----

Storage Room by Janitorial Supply

11	Fittings associated with Fiberglass Pipe Insulation	5	LF
----	--	---	----

Throughout Rooms (under unit ventilators)

32	9" Tan and Beige Speckled Floor Tile/Mastic	600	SF
----	---	-----	----

Unassigned Room 23

01	Pipe Insulation	100	LF
----	-----------------	-----	----

Second Floor

Exterior

47	Exterior Window Caulk (Second Layer)	800	SF
----	---	-----	----

Greenhouse

03	Transite Panel	6	SF
----	----------------	---	----

Hallway

01	Pipe Insulation	40	LF
----	-----------------	----	----

03	Transite Panel	140	SF
----	----------------	-----	----

36	Transite Pipe	20	LF
----	---------------	----	----

Throughout Rooms (under unit ventilators)

32	9" Tan and Beige Speckled Floor Tile/Mastic	600	SF
----	---	-----	----



Appendix C

Material Reports and Analytical Data

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 01
Material Name: Pipe Insulation
Type of Material: Thermal

Material Contains >1%
Asbestos:
Yes (prev. sampled)

Level	Location	Amount	Units
First Floor			
	Conference Room 120	20	LF
	Department of Nursing Main Office 106	10	LF
	Hallway	1,000	LF
	Learning 102	200	LF
	Room 103 Student Success Program	20	LF
	Room 107	20	LF
	Room 108	20	LF
	Room 110	20	LF
	Room 111	18	LF
	Room 126	12	LF
	Room 128	10	LF
Ground Floor			
	11E Clinician's Room	30	LF
	Communication Disorder and Sciences	60	LF
	Hallway	1,000	LF
	Mechanical Room	250	SF
	Room 16	10	LF
	Server Room	30	LF
	Unassigned Room 23	100	LF
Second Floor			
	Hallway	40	LF
Total		2,870	LF

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 03
Material Name: Transite Panel
Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
Yes (prev. sampled)

Level	Location	Amount	Units
First Floor			
	Hallway	140	SF
Ground Floor			
	Hallway	140	SF
Second Floor			
	Greenhouse	6	SF
	Hallway	140	SF
Total		426	SF

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 04
Material Name: 12" Tan Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Hallway	1,650	SF
	Nursing Department Learning Center 123	425	SF
	Room 104	960	SF
	Room 107	1,040	SF
	Room 108	780	SF
	Room 110	150	SF
	Room 122	835	SF
	Room 128	835	SF
	Room 130	440	SF
Ground Floor			
	Hallway	1,650	SF
Total		8,765	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
04 - 01	12/30/2015	Ground Floor Hallway
04 - 02	12/30/2015	First Floor Hallway

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 05
Material Name: Black Cove Base Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Learning Center 102	100	LF
	Room 103 Student Success Program	75	LF
	Room 108	100	LF
	Room 110	45	LF
	Room 111	110	LF
Ground Floor			
	10A-G Therapy Suites	120	LF
	11E Clinician's Room	40	LF
	4A Speech and Hearing Science Laboratory	60	LF
	5A-E Therapy Suites	110	LF
	6A Language Facilitation Computer Lab	60	LF
	Communication Disorder and Sciences	120	LF
	Custodial Slopink	32	LF
	Hallway	405	LF
	Rear Hallway by Storage 26	80	LF
	Room 16	70	LF
	Room 9 Observation Room	40	LF
	Rooms 6C/6D	40	LF
	Speech and Hearing Clinic 11A-11C	100	LF
	Unassigned Room 23	40	LF
Second Floor			
	Nursing Department Offices 214	125	LF
	Room 236	60	LF
Total		1,932	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
05 - 03	12/30/2015	Ground Floor Hallway
05 - 04	12/30/2015	Room 111

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 06

Material Name: 2'x2' Fissured Lay-in Ceiling Tile

Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

Level	Location	Amount	Units
First Floor			
	Auditorium	300	SF
	Custodial Slop sink	48	SF
	Department of Nursing Main Office 106	520	SF
	Hallway	1,650	SF
	Learning Center 102	720	SF
	Men's Restroom	200	SF
	Nursing Department Learning Center 123	425	SF
	Room 103 Student Success Program	320	SF
	Room 104	960	SF
	Room 111	835	SF
	Room 122	835	SF
	Room 124	255	SF
	Room 128	835	SF
	Room 129	440	SF
	Room 130	440	SF
	Women's Restroom	200	SF
Ground Floor			
	Hallway	1,650	SF
	Room 16	625	SF
Second Floor			
	220 Drawing Studio	144	SF
	Custodial Slop sink	48	SF
	Hallway	1,650	SF
	Room 221	480	SF
	Room 232	835	SF
	Room 233	835	SF
	Room 237	835	SF
	Room 238	675	SF
	Room 239	835	SF
	Room 241	835	SF
Total		18,430	SF

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Sampling Data		
<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
06 – 05	12/30/2015	Ground Floor Hallway
06 – 06	12/30/2015	Room 130

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 07
Material Name: 12" Beige Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Room 129	440	SF
Ground Floor			
	10A-G Therapy Suites	830	SF
	11E Clinician's Room	420	SF
	4A Speech and Hearing Science Laboratory	315	SF
	5A-E Therapy Suites	835	SF
	6A Language Facilitation Computer Lab	290	SF
	7A-E Faculty Offices	325	SF
	Communication Disorder and Sciences	835	SF
	Elevator	35	SF
	Room 16	625	SF
	Speech and Hearing Clinic 11A-11C	835	SF
	Storage across from Janitorial Supply	195	SF
Second Floor			
	Nursing Department Offices 214	875	SF
	Room 221	480	SF
	Room 232	835	SF
	Room 233	835	SF
	Room 234	150	SF
	Room 235	100	SF
	Room 236	145	SF
	Room 238	675	SF
	Room 239	835	SF
	Room 241	835	SF
Total		11,745	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
07 13	12/30/2015	Room 16
07 - 14	12/30/2015	Room 16

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 08
Material Name: Glue Dots associated with Chalkboard
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>First Floor</i>			
	Classrooms	500	SF
<i>Ground Floor</i>			
	Classrooms	500	SF
<i>Second Floor</i>			
	Classrooms	500	SF
<i>Total</i>		1,500	SF

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 09
Material Name: Slate Window Sill
Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

Level	Location	Amount	Units
First Floor			
	Department of Nursing Main Offices 106	25	SF
	Learning Center 102	25	SF
	Men's Restroom	20	SF
	Nursing Department Learning Center 123	20	SF
	Room 103 Student Success Program	20	SF
	Room 104	35	SF
	Room 107	35	SF
	Room 108	25	SF
	Room 109	20	SF
	Room 111	25	SF
	Room 122	30	SF
	Room 125	25	SF
	Room 128	25	SF
	Room 129	25	SF
	Room 130	25	SF
	Women's Restroom	20	SF
Ground Floor			
	10A-G Therapy Suites	35	SF
	11E Clinician's Room	20	SF
	4A Speech and Hearing Science Laboratory	20	SF
	5A-E Therapy Suites	35	SF
	6A Language Facilitation Computer Lab	20	SF
	7A-E Faculty Offices	35	SF
	Communication Disorder and Sciences	35	SF
	Room 16	25	SF
	Rooms 6C/6D	20	SF
	Speech and Hearing Clinic 11A-11C	25	SF
Second Floor			
	217 Offices	35	SF
	218 Offices	35	SF
	220 Doctoral Nursing Practice Program	35	SF

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 09
Material Name: Slate Window Sill
Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

Level	Location	Amount	Units
	Men's Restroom	20	SF
	Nursing Department Offices 214	25	SF
	Room 221	25	SF
	Room 232	35	SF
	Room 233	35	SF
	Room 236	20	SF
	Room 239	35	SF
	Room 240	35	SF
	Room 241	35	SF
	Women's Restroom	20	SF
	<i>Total</i>	1,060	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
09 - 07	12/30/2015	Room 111
09 08	12/30/2015	Room 130

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No:	10	<i>Material Contains >1% Asbestos: Yes (prev. sampled)</i>
Material Name:	Tank Insulation	
Type of Material:	Miscellaneous	

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>Ground Floor</i>			
	Mechanical Room	200	LF
	<i>Total</i>	200	LF

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 11

Material Name: Fittings associated with Fiberglass
Pipe Insulation

Type of Material: Thermal

*Material Contains >1%
Asbestos:*
Yes (prev. sampled)

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>First Floor</i>			
	Auditorium	80	LF
	Conference Room 120	6	LF
	HW 125	8	LF
	Room 130	2	LF
<i>Ground Floor</i>			
	10A-G Therapy Suites	1	LF
	4A Speech and Hearing Science Laboratory	16	LF
	5A-E Therapy Suites	5	LF
	6A Language Facilitation Computer Lab	6	LF
	7A-E Faculty Offices	6	LF
	Mechanical Room	70	LF
	Room outside Janitorial Supply	3	LF
	Rooms 6C/6D	15	LF
	Server Room	15	LF
	Storage Room by Janitorial Supply	5	LF
	<i>Total</i>	238	LF

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 12
Material Name: Drywall
Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

Level	Location	Amount	Units
First Floor			
	Auditorium	1,500	SF
	Department of Nursing Main Office 106	600	SF
	Room 103 Student Success Program	125	SF
	Room 125	300	SF
Ground Floor			
	10A-G Therapy Suites	650	SF
	11E Clinician's Room	325	SF
	4A Speech and Hearing Science Laboratory	30	SF
	5A-E Therapy Suites	350	SF
	6A Language Facilitation Computer Lab	800	SF
	7A-E Faculty Offices	825	SF
	Communication Disorder and Sciences	825	SF
	Custodial Break Room	215	SF
	Custodial Supply Room	215	SF
	Electrical Closet/Storage 26	80	SF
	Janitorial Supply Room	50	SF
	Rear Hall by Storage 26	450	SF
	Room 9 Observation Room	325	SF
	Server Room	300	SF
	Speech and Hearing Clinic 11A-11C	400	SF
	Storage across from Janitorial Supply	195	SF
	Unassigned Room 23	200	SF
Second Floor			
	217 Offices	850	SF
	217 Offices	850	SF
	Nursing Department Offices 214	600	SF
	Room 221	200	SF
	Room 240	200	SF
Total		11,460	SF

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Sampling Data		
<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
12 – 09	12/30/2015	Custodial Break Room
12 – 10	12/30/2015	Custodial Supply Room

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 13
Material Name: Joint Compound
Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

Level	Location	Amount	Units
First Floor			
	Auditorium	200	LF
	Department of Nursing Main Office 106	55	SF
	Room 103 Student Success Program	20	SF
	Room 125	20	SF
Ground Floor			
	10A-G Therapy Suites	45	SF
	11E Clinician's Room	25	SF
	4A Speech and Hearing Science Laboratory	5	SF
	5A-E Therapy Suites	25	LF
	6A Language Facilitation Computer Lab	50	LF
	7A-E Faculty Offices	50	LF
	Communication Disorder and Sciences	55	SF
	Custodial Break Room	25	SF
	Custodial Supply Room	25	SF
	Electrical Closet/Storage 26	10	SF
	Janitorial Supply Room	15	SF
	Rear Hall by Storage 26	50	SF
	Room 9 Observation Room	35	LF
	Server Room	30	LF
	Speech and Hearing Clinic 11A-11C	25	SF
	Storage across from Janitorial Supply	30	SF
	Unassigned Room 23	30	SF
Second Floor			
	217 Offices	75	LF
	217 Offices	75	SF
	Nursing Department Offices 214	55	SF
	Room 221	15	SF
	Room 240	25	LF
Total		1,070	LF

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Sampling Data		
<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
13 – 11	12/30/2015	Custodial Break Room
13 – 12	12/30/2015	Custodial Supply Room

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 15
Material Name: 2'x4' Lay-in Ceiling Tile
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Ground Floor			
	10A-G Therapy Suites	830	SF
	11E Clinician's Room	420	SF
	4A Speech and Hearing Science Laboratory	315	SF
	5A-E Therapy Suites	835	SF
	6A Language Facilitation Computer Lab	290	SF
	7A-E Faculty Offices	835	SF
	Communication Disorder and Sciences	835	SF
	Room 9 Observation Room	150	SF
	Rooms 6C/6D	835	SF
	Speech and Hearing Clinic 11A-11C	835	SF
	Storage across from Janitorial Supply	195	SF
Second Floor			
	220 Doctoral Nursing Practice Program	500	SF
	Nursing Department Offices 214	875	SF
	Room 236	145	SF
	Room 240	835	SF
Total		8,730	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
15 – 15	12/30/2015	Nursing Department Offices 214
15 – 16	12/30/2015	Storage across from Janitorial Supply

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 16
Material Name: 2'x2' Textured Ceiling Tile
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Ground Floor			
	Rear Hall by Storage 26	80	SF
Second Floor			
	217 Offices	835	SF
	218 Offices	835	SF
Total		1,750	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
16 – 17	12/30/2015	Rear Hall by Storage
16 – 18	12/30/2015	217 Offices

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 18
Material Name: Brown Cove Base Mastic
Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

Level	Location	Amount	Units
First Floor			
	Nursing Department Learning Center 123	60	LF
	Room 104	120	LF
	Room 107	120	LF
	Room 122	60	LF
	Room 124	60	LF
	Room 128	120	LF
	Room 129	80	LF
	Room 130	80	LF
Second Floor			
	Custodial Slop sink	20	LF
	Room 221	80	LF
	Room 232	60	LF
	Room 233	60	LF
	Room 234	40	LF
	Room 235	40	LF
	Room 238	60	LF
	Room 240	60	LF
Total		1,120	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
18 – 19	12/30/2015	Room 129
18 – 20	12/30/2015	Room 107

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 19

Material Name: 12" Black and White Speckled
Floor Tile/Mastic

Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Custodial Slopsink	48	SF
	Men's Restroom	15	SF
Second Floor			
	Custodial Slopsink	48	SF
	Men's Restroom	15	SF
Total		126	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
19 – 21	12/30/2015	First Floor Custodial Slopsink
19 – 22	12/30/2015	First Floor Custodial Slopsink

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 23
Material Name: Ceramic Tile Grout
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Men's Restroom	320	SF
	Women's Restroom	320	SF
Second Floor			
	Men's Restroom	320	SF
	Women's Restroom	320	SF
Total		1,280	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
23 - 23	12/30/2015	First Floor Women's Restroom
23 - 24	12/30/2015	2nd Floor Women's Restroom

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 24
Material Name: 12" Multi-color Speckled Floor
Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Women's Restroom	15	SF
Second Floor			
	Women's Restroom	15	SF
Total		30	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
24 – 25	12/30/2015	First Floor Women's Restroom
24 – 26	12/30/2015	First Floor Women's Restroom

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 25
Material Name: 12" Black Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Auditorium	20	SF
	Women's Restroom	15	SF
	<i>Total</i>	35	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
25 – 27	12/30/2015	First Floor Women's Restroom
25 – 28	12/30/2015	Auditorium Closet

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 26
Material Name: 12" Tan with Grey Streaks Floor
Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Room 111	835	SF
	<i>Total</i>	835	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
26 - 29	12/30/2015	Room 111
26 - 30	12/30/2015	Room 111

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 27

Material Name: 12" Spline Ceiling Tile

Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

Level	Location	Amount	Units
First Floor			
	Learning Center 102	25	SF
	Room 104	25	SF
	Room 107	25	SF
	Room 108	25	SF
	Room 111	25	SF
	Room 122	25	SF
	Room 125	25	SF
Ground Floor			
	10A-G Therapy Suites	25	SF
	11E Clinician's Room	25	SF
	5A-E Therapy Suites	25	SF
	6A Language Facilitation Computer Lab	25	SF
	7A-E Faculty Offices	25	SF
	Rooms 6C/6D	25	SF
	Speech and Hearing Clinic 11A-11C	25	SF
Second Floor			
	217 Offices	25	SF
	218 Offices	25	SF
	220 Doctoral Nursing Practice Program	25	SF
	Room 232	25	SF
	Room 233	25	SF
	Room 237	25	SF
	Room 238	25	SF
	Room 239	25	SF
	Room 240	25	SF
	Room 241	25	SF
Total		600	SF

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Sampling Data		
<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
27 – 31	12/30/2015	Room 111
27 – 32	12/30/2015	Room 108

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Homogeneous No: 28

Material Name: Glue Dots associated with 12"
Spline Ceiling Tile

Type of Material: Miscellaneous

Material Contains >1%
Asbestos:
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Learning Center 102	25	SF
	Room 104	25	SF
	Room 107	25	SF
	Room 108	25	SF
	Room 111	25	SF
	Room 122	25	SF
	Room 125	25	SF
Ground Floor			
	10A-G Therapy Suites	25	SF
	11E Clinician's Room	25	SF
	5A-E Therapy Suites	25	SF
	6A Language Facilitation Computer Lab	25	SF
	7A-E Faculty Offices	25	SF
	Rooms 6C/6D	25	SF
	Speech and Hearing Clinic 11A-11C	25	SF
Second Floor			
	217 Offices	25	SF
	218 Offices	25	SF
	220 Doctoral Nursing Practice Program	25	SF
	Room 232	25	SF
	Room 233	25	SF
	Room 237	25	SF
	Room 238	25	SF
	Room 239	25	SF
	Room 240	25	SF
	Room 241	25	SF
Total		600	SF

Material Report

Client: William Paterson University

Facility: Hunziker Wing

Date: 2/3/2015

Project No: 14-1532

Sampling Data		
<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
28 – 33	12/30/2015	Room 108
28 – 34	12/30/2015	Room 107

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 30
Material Name: 2'x2' Smooth White Lay-in Ceiling Tile
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Room 108	780	SF
	Room 125	400	SF
	Total	1,180	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
30 – 35	12/30/2015	Room 108
30 – 36	12/30/2015	Room 125

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 32

Material Name: 9" Tan and Beige Speckled Floor
Tile/Mastic

Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
Yes

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
<i>First Floor</i>			
	Conference Room 120	500	SF
	Learning 102	780	SF
	Room 104	20	SF
	Room 107	60	SF
	Room 124	255	SF
	Room 126	225	SF
	Throughout Rooms (under unit ventilators)	600	SF
<i>Ground Floor</i>			
	Throughout Rooms (under unit ventilators)	600	SF
<i>Second Floor</i>			
	Throughout Rooms (under unit ventilators)	600	SF
<i>Total</i>		3,640	SF

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 33
Material Name: Green Cove Base Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Department of Nursing Main Office 106	120	LF
	<i>Total</i>	120	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
33 – 39	12/30/2015	Department of Nursing 106
33 40	12/30/2015	Department of Nursing 106

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 35
Material Name: Brown Duct Insulation
Type of Material: Thermal

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Second Floor			
	Mechanical Room	80	SF
	<i>Total</i>	80	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
35 – 41	12/30/2015	Second Floor Mechanical Room
35 42	12/30/2015	Second Floor Mechanical Room

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No:	36	<i>Material Contains >1% Asbestos: Yes (assumed)</i>
Material Name:	Transite Pipe	
Type of Material:	Miscellaneous	

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Second Floor			
	Hallway	20	LF
	<i>Total</i>	20	LF

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 37
Material Name: Gray Cove Base
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Second Floor			
	217 Offices	100	LF
	218 Offices	100	LF
	220 Doctoral Nursing Practice Program	80	LF
	<i>Total</i>	280	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
37 – 43	12/30/2015	217 Offices
37 – 44	12/30/2015	220 Doctoral Nursing Practice Program

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 38
Material Name: 12" Green with Black Specks Floor Tile/Mastic
Type of Material: Miscellaneous

Material Contains >1% Asbestos:
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Second Floor			
	Women's Restroom	15	SF
	<i>Total</i>	15	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
38 - 45	12/30/2015	Second Floor Women's Restroom
38 - 46	12/30/2015	Second Floor Women's Restroom

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 39
Material Name: 12" Tan with Black Specks Floor
Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Second Floor			
	Men's Restroom	15	SF
	<i>Total</i>	15	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
39 - 47	12/30/2015	Second Floor Men's Restroom
39 - 48	12/30/2015	Second Floor Men's Restroom

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 40

Material Name: Interior Brick Mortar

Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Throughout	3,200	SF
Ground Floor			
	Throughout	3,200	SF
Second Floor			
	Throughout	3,200	SF
Total		9,600	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
40 - 49	12/30/2015	Ground Floor Hallway
40 - 50	12/30/2015	First Floor Hallway

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No:	41	<i>Material Contains >1% Asbestos: Yes</i>
Material Name:	12" Gray and White Floor Tile/Mastic	
Type of Material:	Miscellaneous	

Level	Location	Amount	Units
Ground Floor	Server Room	250	SF
	Total	250	SF

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 42
Material Name: 12" Tan with Brown Streaks Floor
Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Ground Floor			
	Server Room	25	SF
	<i>Total</i>	25	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
42 - 53	12/30/2015	Server Room
42 - 54	12/30/2015	Server Room

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 43
Material Name: 9" Tan Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
Yes

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Ground Floor			
	7A-E Faculty Offices	520	SF
	Elevator	35	SF
	Room 9 Observation Room	150	SF
	Rooms 6C/6D	300	SF
	<i>Total</i>	1,005	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
43 – 55	12/30/2015	Room 6C/6D
43 – 56	12/30/2015	Room 6C/6D

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No:	44	<i>Material Contains >1% Asbestos: Yes</i>
Material Name:	Cream Floor Tile/Mastic	
Type of Material:	Miscellaneous	

Level	Location	Amount	Units
Ground Floor	Elevator	35	SF
Total		35	SF

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 45
Material Name: 12" Light Green Floor Tile/Mastic
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Ground Floor			
	Elevator	35	SF
	<i>Total</i>	35	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
45 – 59	12/30/2015	Elevator
45 – 60	12/30/2015	Elevator

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 46
Material Name: Exterior Window Caulk (Top Layer)
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Exterior	800	LF
Ground Floor			
	Exterior	800	LF
Second Floor			
	Exterior	800	LF
Total		2,400	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
46 61	12/30/2015	Exterior
46 – 62	12/30/2015	Exterior

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 47
Material Name: Exterior Window Caulk (Second Layer)
Type of Material: Miscellaneous

Material Contains >1% Asbestos:
Yes

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Exterior	800	SF
Ground Floor			
	Exterior	800	SF
Second Floor			
	Exterior	800	SF
Total		2,400	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
47 – 63	12/30/2015	Exterior
47 – 64	12/30/2015	Exterior

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 48
Material Name: Exterior Door Caulk
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
Yes

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
Ground Floor			
	Exterior	25	LF
	<i>Total</i>	25	LF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
48 – 65	12/30/2015	Exterior
48 – 66	12/30/2015	Exterior

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 49
Material Name: Exterior Red Brick Mortar
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Exterior	1,200	SF
Ground Floor			
	Exterior	1,200	SF
Second Floor			
	Exterior	1,200	SF
Total		3,600	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
49 - 67	12/30/2015	Exterior
49 - 68	12/30/2015	Exterior

Material Report

Client: William Paterson University
Facility: Hunziker Wing
Date: 2/3/2015
Project No: 14-1532

Homogeneous No: 50
Material Name: Tan Brick Mortar
Type of Material: Miscellaneous

*Material Contains >1%
Asbestos:*
No

<i>Level</i>	<i>Location</i>	<i>Amount</i>	<i>Units</i>
First Floor			
	Exterior	3,200	SF
Ground Floor			
	Exterior	3,200	SF
Second Floor			
	Exterior	3,200	SF
Total		9,600	SF

Sampling Data

<u>Sample No.</u>	<u>Date of Sampling</u>	<u>Location of Sampling</u>
50 - 69	12/30/2015	Exterior
50 - 70	12/30/2015	Exterior



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

90. 016993

E-MAIL ALL RESULTS AND COC TO: h-jablab@ttienv.com

PLM Sampling Data and Chain of Custody Record

PROJECT #: 14-1578		CLIENT: William Paterson Univ.		TTI PROJECT MANAGER:		Ox Jim Guillard Michael Stocku J-S	
SAMPLER(S): J-S		CLIENT CONTACT: A.S.		FACILITY: Henziker wing		DATE: 12/30/14	
Sample #	Sample Location	Material Description	Sample Container	PO No.	Hour Turnaround Time	Stop At First Positive	
04-01	Ground Floor Hallway	12" Tan F.T. / mastic	Whirl Pak				
04-02	1st Floor Hallway	12" Tan F.T. / mastic					
05-03	Ground Floor Hallway	Black core base mastic					
05-04	Room 111	Black core base mastic					
06-05	Ground Floor Hallway	2x2 Lay-in ceiling Tile					
06-06	Room 130	2x2 Lay-in ceiling Tile					
09-07	Room 111	window slate					
09-08	Room 130	window slate					
12-09	Custodial Break Room	Drywall					
12-10	Custodial Supply Room	Drywall					
13-11	Custodial Break Room	Joint Compound					
13-12	Custodial Supply Room	Joint Compound					
07-13	Room 16	12" Beige F.T. / mastic					
07-14	Room 16	12" Beige F.T. / mastic					
15-15	Nursing Dept. offices 214	2x4 Lay-in ceiling Tile					
15-16	Storage across from Janitorial	2x4 Lay-in ceiling Tile					
16-17	Reor Hall by Storage	2x2 Textured Lay-in ceiling Tile					
16-18	217 office	2x2 Textured Lay-in ceiling Tile					
Relinquished by: (Signature)	Date: 2/14/15	Received by: (Signature)	Date:	PO No.	Hour Turnaround Time	Stop At First Positive	
Relinquished by: (Signature)	Date:	Received by: (Signature)	Date:				

NOB MATERIALS:
☒ Perform TEM analysis of 1st sample in each homogeneous group. (Initials: SSON)
☒ For NOB samples with insufficient material for TEM analysis, please perform composite analysis using material from other samples in the same homogeneous group. (Initials: SSON)

2015 FEB 14 8:31



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

E-MAIL ALL RESULTS AND COC TO: h-lablab@ttienv.com

PLM Sampling Data and Chain of Custody Record

PROJECT #: 14-1578	CLIENT: William Patterson Univ.	TTI PROJECT MANAGER: Ox Jim Guillard O Michael Stocku	DATE: 12/30/14
SAMPLER(S): J.S.	CLIENT CONTACT: R.S.	FACILITY: Hunziker Wing	

Sample #	Sample Location	Material Description	Sample Container
18-19	Room 129	Brown cave base mastic	Whirl Pak
18-20	Room 107	Brown cave base mastic	
19-21	1st Floor Custodial Stopsink	12" Black + white speckled F.T. mastic	
19-22	1st Floor Custodial Stopsink	12" Black + white speckled F.T. mastic	
23-23	1st Floor women's Room	Ceramic Tile Grout	
23-24	2nd Floor women's Room	Ceramic Tile Grout	
24-25	1st Floor women's Restroom	12" Multi-colored speckled F.T. mastic	
24-26	1st Floor women's Restroom	12" Multi-colored speckled F.T. mastic	
25-27	1st Floor women's Restroom	12" Black F.T. mastic	
25-28	Auditorium closet	12" Black F.T. mastic	
26-29	Room 111	12" Tan w/ Gray streaks F.T. mastic	
26-30	Room 111	12" Tan w/ Gray streaks F.T. mastic	
27-31	Room 111	12" Spline ceiling Tile	
27-32	Room 108	12" Spline ceiling Tile	
28-33	Room 108	Glue dots assoc. w/ 12" spline	
28-34	Room 107	Glue dots assoc. w/ 12" spline	
30-35	Room 108	2x2 smooth white lay-in C.T.	
30-36	Room 125	2x2 smooth white lay-in C.T.	

Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time	PO No.	Hour Turnaround Time	Stop At First Positive
[Signature]							24	<input checked="" type="checkbox"/>
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time	NOB MATERIALS: <input checked="" type="checkbox"/> Perform TEM analysis of 1st sample in each homogeneous group. (Initials) <input checked="" type="checkbox"/> For NOB samples with insufficient material for TEM analysis, please perform composite analysis using material from other samples in the same homogeneous group. (Initials)		



1253 North Church Street, Morristown, NJ 08057
856-840-8800 Fax 856-840-8815

041504190

E-MAIL ALL RESULTS AND COC TO: ih-lablab@ttienv.com

PLM Sampling Data and Chain of Custody Record

PROJECT #: 14-1578		CLIENT: William Paterson Univ.		TTI PROJECT MANAGER:		Ox Jim Guillard Michael Stocky		DATE: 4/30/14	
SAMPLER(S): J.S.		CLIENT CONTACT: M.S.		FACILITY: Hunziker wing				Sample Container	
Sample #	Sample Location	Date	Time	Material Description	Sample Container				
32-37	Room 107			9" Tan + Beige speckled F.T./mastic	Whit/Red				
32-38	Room 124			9" Tan + Beige speckled F.T./mastic					
33-39	Dept. of Nursing 106			Green core base mastic					
33-40	Dept. of Nursing 106			Green core base mastic					
35-41	2nd Floor Mechanical Rm			Brown flat Insulation					
35-42	2nd Floor Mechanical Rm			Brown flat Insulation					
37-43	217 offices			Gray core base mastic					
37-44	220 Doctoral Nursing Practice Program			Gray core base mastic					
38-45	2nd Floor women's Restroom			12" Green w/ Black specks F.T./mastic	2015 FEB 14				
38-46	2nd Floor women's Restroom			12" Green w/ Black specks F.T./mastic					
39-47	2nd Floor Men's Restroom			12" Tan w/ Black specks F.T./mastic					
39-48	2nd Floor Men's Restroom			12" Tan w/ Black specks F.T./mastic					
40-49	Grand Floor Hallway			Interior Brick Mortar					
40-50	1st Floor Hallway			Interior Brick Mortar					
41-51	Server Room			12" Gray + white F.T./mastic					
41-52	Server Room			12" Gray + white F.T./mastic					
42-53	Server Room			12" Tan w/ Brown F.T./mastic					
42-54	Server Room			12" Tan w/ Brown F.T./mastic					
Relinquished by: (Signature)		Date	Time	Received by: (Signature)	Date	Time	PO No.	Hour Turnaround Time	Stop At First Positive
Relinquished by: (Signature)		Date	Time	Received by: (Signature)	Date	Time		24	

NOB MATERIALS:

Perform TEM analysis of 1st sample in each homogeneous group. (Initials) JS
For NOB samples with insufficient material for TEM analysis, please perform composite analysis using material from other samples in the same homogeneous group. (Initials) JS



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

E-MAIL ALL RESULTS AND COC TO: ih-lablab@ttienv.com

041504190

PLM Sampling Data and Chain of Custody Record

PROJECT #: 14-1578	CLIENT: William Peterson Univ.	TTI PROJECT MANAGER: Ox Jim Guillard O Michael Stocku	J.S.
SAMPLER(S): J.S.	CLIENT CONTACT: M.S.	FACILITY: Hunziker wing	DATE: 12/30/14

Sample #	Sample Location	Material Description	Sample Container
43-53	Room 64/6D	9" Tan F.T. / mastic	Whirl Pak
43-56	Room 64/6D	9" Tan F.T. / mastic	
44-57	Elevator	cream F.T. (Bottom layer) mastic	
44-58	Elevator	cream F.T. (Bottom layer) mastic	
45-59	Elevator	12" Lt. green F.T.	
45-60	Elevator	12" Lt. green F.T.	
46-61	Exterior	Top layer window caulking	
46-62	Exterior	Top layer window caulking	
47-63	Exterior	window caulking (Inner layer)	
47-64	Exterior	window caulking (Inner layer)	
48-65	Exterior	Door caulking	
48-66	Exterior	Door caulking	
49-67	Exterior	Red Birch Mortar	
49-68	Exterior	Red Birch Mortar	
50-69	Exterior	Tan Birch Mortar	
50-70	Exterior	Tan Birch Mortar	

2015 FEB 4 A 8:31
 CINNAPLUS, N.J.

Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time	PO No.	Hour Turnaround Time	Stop At First Positive
							<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time	NOB MATERIALS: <input checked="" type="checkbox"/> Perform TEM analysis of 1 st sample in each homogeneous group. (Initials) <input checked="" type="checkbox"/> For NOB samples with insufficient material for TEM analysis, please perform composite analysis using material from other samples in the same homogeneous group. (Initials)		



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnaslab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson Univ

Attn: Jim Guillard
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
Fax: (856) 840-8815
Collected: 12/30/2014
Received: 2/14/2015
Analyzed: 2/25/2015

Proj: 14-1578 / William Paterson Univ / Hunziker Wing (William Paterson Univ)

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 04-01-Floor Tile

Lab Sample ID: 041504190-0001

Sample Description: Ground Floor Hallway/12" Tan FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Tan	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Tan	0.0%	100%	None Detected	

Client Sample ID: 04-01-Mastic

Lab Sample ID: 041504190-0001A

Sample Description: Ground Floor Hallway/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Black	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Black	0.0%	100%	None Detected	

Client Sample ID: 04-02-Floor Tile

Lab Sample ID: 041504190-0002

Sample Description: 1st Floor Hallway/12" Tan FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Tan	0%	100%	None Detected	

Client Sample ID: 04-02-Mastic

Lab Sample ID: 041504190-0002A

Sample Description: 1st Floor Hallway/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Black	0%	100%	None Detected	

Client Sample ID: 05-03

Lab Sample ID: 041504190-0003

Sample Description: Ground Floor Hallway/Black Cove Base Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Tan	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Tan	0.0%	100%	None Detected	

Client Sample ID: 05-04

Lab Sample ID: 041504190-0004

Sample Description: Room 111/Black Cove Base Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Tan	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnaslab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 06-05 Lab Sample ID: 041504190-0005

Sample Description: Ground Floor Hallway/2'x2' Lay-in Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray/White	80%	20%	None Detected	

Client Sample ID: 06-06 Lab Sample ID: 041504190-0006

Sample Description: Room 130/2'x2' Lay-in Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Gray/White	80%	20%	None Detected	

Client Sample ID: 09-07 Lab Sample ID: 041504190-0007

Sample Description: Room 111/Window Slate

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Black	0%	100%	None Detected	

Client Sample ID: 09-08 Lab Sample ID: 041504190-0008

Sample Description: Room 130/Window Slate

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Black	0%	100%	None Detected	

Client Sample ID: 12-09 Lab Sample ID: 041504190-0009

Sample Description: Custodial Break Room/Drywall

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Brown/White	20%	80%	None Detected	

Client Sample ID: 12-10 Lab Sample ID: 041504190-0010

Sample Description: Custodial Supply Room/Drywall

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Brown/White	20%	80%	None Detected	

Client Sample ID: 13-11 Lab Sample ID: 041504190-0011

Sample Description: Custodial Break Room/Joint Compound

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	White	0%	100%	None Detected	

Client Sample ID: 13-12 Lab Sample ID: 041504190-0012

Sample Description: Custodial Supply Room/Joint Compound

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	White	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 07-13-Floor Tile **Lab Sample ID:** 041504190-0013

Sample Description: Room 16/12" Beige FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Beige	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Beige	0.0%	100%	None Detected	

Client Sample ID: 07-13-Mastic

Lab Sample ID: 041504190-0013A

Sample Description: Room 16/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Black	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Black	0.0%	100%	None Detected	

Client Sample ID: 07-14-Floor Tile

Lab Sample ID: 041504190-0014

Sample Description: Room 16/12" Beige FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Beige	0%	100%	None Detected	

Client Sample ID: 07-14-Mastic

Lab Sample ID: 041504190-0014A

Sample Description: Room 16/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Black	0%	100%	None Detected	

Client Sample ID: 15-15

Lab Sample ID: 041504190-0015

Sample Description: Nursing Dept Offices 214/2'x4' Lay-in Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray/White	70%	30%	None Detected	

Client Sample ID: 15-16

Lab Sample ID: 041504190-0016

Sample Description: Storage Across from Janitorial Supply/2'x4' Lay-in Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Gray/White	80%	20%	None Detected	

Client Sample ID: 16-17

Lab Sample ID: 041504190-0017

Sample Description: Rear Hall by Storage/2'x2' Textured Lay-in Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray/White	85%	15%	None Detected	

Client Sample ID: 16-18

Lab Sample ID: 041504190-0018

Sample Description: 217 Office/2'x2' Textured Lay-in Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Gray/White	80%	20%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 18-19 **Lab Sample ID:** 041504190-0019

Sample Description: Room 129/Brown Cove Base Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Brown	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Brown	0.0%	100%	None Detected	

Client Sample ID: 18-20 **Lab Sample ID:** 041504190-0020

Sample Description: Room 107/Brown Cove Base Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Brown	0%	100%	None Detected	

Client Sample ID: 19-21-Floor Tile **Lab Sample ID:** 041504190-0021

Sample Description: 1st Floor Custodial Slopink/12" Black & White Sepckled FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	White/Black	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	White/Black	0.0%	100%	None Detected	

Client Sample ID: 19-21-Mastic **Lab Sample ID:** 041504190-0021A

Sample Description: 1st Floor Custodial Slopink/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015				Insufficient Material	

Client Sample ID: 19-22-Floor Tile **Lab Sample ID:** 041504190-0022

Sample Description: 1st Floor Custodial Slopink/12" Black & White Sepckled FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	White/Black	0%	100%	None Detected	

Client Sample ID: 19-22-Mastic **Lab Sample ID:** 041504190-0022A

Sample Description: 1st Floor Custodial Slopink/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Yellow	0%	100%	None Detected	

Client Sample ID: 23-23 **Lab Sample ID:** 041504190-0023

Sample Description: 1st Floor Women's Room/Ceramic Tile Grout

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	White	0%	100%	None Detected	

Client Sample ID: 23-24 **Lab Sample ID:** 041504190-0024

Sample Description: 2nd Floor Women's Room/Ceramic Tile Grout

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	White	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnaslab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 24-25-Floor Tile **Lab Sample ID:** 041504190-0025
Sample Description: 1st Floor Women's Room/12" Multi-Colored Speckled FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	White/Various	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	White/Various	0.0%	100%	None Detected	

Client Sample ID: 24-25-Mastic **Lab Sample ID:** 041504190-0025A
Sample Description: 1st Floor Women's Room/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray/Yellow	0%	100%	None Detected	Inseparable leveling compound attached
TEM Grav. Reduction	2/17/2015	Gray/Yellow	0.0%	100%	None Detected	

Client Sample ID: 24-26-Floor Tile **Lab Sample ID:** 041504190-0026
Sample Description: 1st Floor Women's Room/12" Multi-Colored Speckled FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	White/Various	0%	100%	None Detected	

Client Sample ID: 24-26-Mastic **Lab Sample ID:** 041504190-0026A
Sample Description: 1st Floor Women's Room/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Gray/Yellow	0%	100%	None Detected	Inseparable leveling compound attached

Client Sample ID: 25-27-Floor Tile **Lab Sample ID:** 041504190-0027
Sample Description: 1st Floor Women's Room/12" Black FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Black	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Black	0.0%	100%	None Detected	

Client Sample ID: 25-27-Mastic **Lab Sample ID:** 041504190-0027A
Sample Description: 1st Floor Women's Room/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015				Insufficient Material	

Client Sample ID: 25-28-Floor Tile **Lab Sample ID:** 041504190-0028
Sample Description: Auditorium Closet/12" Black FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Black	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 25-28-Mastic **Lab Sample ID:** 041504190-0028A

Sample Description: Auditorium Closet/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Yellow	0%	100%	None Detected	

Client Sample ID: 26-29-Floor Tile

Lab Sample ID: 041504190-0029

Sample Description: Room 111/12" Tan w/ Gray Streaks FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray/Tan	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Gray/Tan	0.0%	100%	None Detected	

Client Sample ID: 26-29-Mastic

Lab Sample ID: 041504190-0029A

Sample Description: Room 111/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Yellow	0.0%	100%	None Detected	

Client Sample ID: 26-30-Floor Tile

Lab Sample ID: 041504190-0030

Sample Description: Room 111/12" Tan w/ Gray Streaks FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Gray/Tan	0%	100%	None Detected	

Client Sample ID: 26-30-Mastic

Lab Sample ID: 041504190-0030A

Sample Description: Room 111/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Yellow	0%	100%	None Detected	

Client Sample ID: 27-31

Lab Sample ID: 041504190-0031

Sample Description: Room 111/12" Spline Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	White/Yellow	95%	5%	None Detected	

Client Sample ID: 27-32

Lab Sample ID: 041504190-0032

Sample Description: Room 108/12" Spline Ceiling Tile

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	White/Yellow	95%	5%	None Detected	

Client Sample ID: 28-33

Lab Sample ID: 041504190-0033

Sample Description: Room 108/Glue Dots a/w 12" Spline

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Brown	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Brown	0.0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 28-34 Lab Sample ID: 041504190-0034

Sample Description: Room 107/Glue Dots a/w 12" Spline

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Brown	0%	100%	None Detected	

Client Sample ID: 30-35 Lab Sample ID: 041504190-0035

Sample Description: Room 108/2'x2' Smooth White Lay-in CT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray/White	80%	20%	None Detected	

Client Sample ID: 30-36 Lab Sample ID: 041504190-0036

Sample Description: Room 125/2'x2' Smooth White Lay-in CT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Gray/White	80%	20%	None Detected	

Client Sample ID: 32-37-Floor Tile Lab Sample ID: 041504190-0037

Sample Description: Room 107/9" Tan & Beige Speckled FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Tan/Beige	0%	92%	8% Chrysotile	

Client Sample ID: 32-37-Mastic Lab Sample ID: 041504190-0037A

Sample Description: Room 107/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015					Stop Positive (Not Analyzed)
TEM Grav. Reduction	2/25/2015	Black	0.0%	96.5%	3.5% Chrysotile	

Client Sample ID: 32-38-Floor Tile Lab Sample ID: 041504190-0038

Sample Description: Room 124/9" Tan & Beige Speckled FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015					Stop Positive (Not Analyzed)

Client Sample ID: 32-38-Mastic Lab Sample ID: 041504190-0038A

Sample Description: Room 124/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015					Stop Positive (Not Analyzed)

Client Sample ID: 33-39 Lab Sample ID: 041504190-0039

Sample Description: Dept of Nursing 106/Green Cove Base Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Tan	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Tan	0.0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnaslab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 33-40 **Lab Sample ID:** 041504190-0040

Sample Description: Dept of Nursing 106/Green Cove Base Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Tan	0%	100%	None Detected	

Client Sample ID: 35-41 **Lab Sample ID:** 041504190-0041

Sample Description: 2nd Floor Mechanical Rm/Brown Duct Insulation

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Black	50%	50%	None Detected	

Client Sample ID: 35-42 **Lab Sample ID:** 041504190-0042

Sample Description: 2nd Floor Mechanical Rm/Brown Duct Insulation

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Brown	10%	90%	None Detected	

Client Sample ID: 37-43 **Lab Sample ID:** 041504190-0043

Sample Description: 217 Offices/Gray Cove Base Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Yellow	0.0%	100%	None Detected	

Client Sample ID: 37-44 **Lab Sample ID:** 041504190-0044

Sample Description: 220 Doctoral Nursing Practice Program/Gray Cove Base Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Yellow	0%	100%	None Detected	

Client Sample ID: 38-45-Floor Tile **Lab Sample ID:** 041504190-0045

Sample Description: 2nd Floor Women's Restroom/12" Green w/ Black Specks FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Black/Green	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Black/Green	0.0%	100%	None Detected	

Client Sample ID: 38-45-Mastic **Lab Sample ID:** 041504190-0045A

Sample Description: 2nd Floor Women's Restroom/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015				Insufficient Material	

Client Sample ID: 38-46-Floor Tile **Lab Sample ID:** 041504190-0046

Sample Description: 2nd Floor Women's Restroom/12" Green w/ Black Specks FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Black/Green	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 38-46-Mastic **Lab Sample ID:** 041504190-0046A

Sample Description: 2nd Floor Women's Restroom/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Yellow	0%	100%	None Detected	

Client Sample ID: 39-47-Floor Tile

Lab Sample ID: 041504190-0047

Sample Description: 2nd Floor Men's Restroom/12" Tan w/ Black Specks FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Tan/Black	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Tan/Black	0.0%	100%	None Detected	

Client Sample ID: 39-47-Mastic

Lab Sample ID: 041504190-0047A

Sample Description: 2nd Floor Men's Restroom/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Yellow	0.0%	100%	None Detected	

Client Sample ID: 39-48-Floor Tile

Lab Sample ID: 041504190-0048

Sample Description: 2nd Floor Men's Restroom/12" Tan w/ Black Specks FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Tan	0%	100%	None Detected	

Client Sample ID: 39-48-Mastic

Lab Sample ID: 041504190-0048A

Sample Description: 2nd Floor Men's Restroom/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Yellow	0%	100%	None Detected	

Client Sample ID: 40-49

Lab Sample ID: 041504190-0049

Sample Description: Ground Floor Hallway/Interior Brick Mortar

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray/White	0%	100%	None Detected	

Client Sample ID: 40-50

Lab Sample ID: 041504190-0050

Sample Description: 1st Floor Hallway/Interior Brick Mortar

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Gray/White	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 41-51-Floor Tile

Lab Sample ID: 041504190-0051

Sample Description: Server Room/12" Gray & White FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray/White	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Gray/White	0.0%	97.5%	0.30% Anthophyllite 2.2% Chrysotile	

Client Sample ID: 41-51-Mastic

Lab Sample ID: 041504190-0051A

Sample Description: Server Room/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Black	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Black	0.0%	100%	None Detected	

Client Sample ID: 41-52-Floor Tile

Lab Sample ID: 041504190-0052

Sample Description: Server Room/12" Gray & White FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Gray/White	0%	100%	None Detected	

Client Sample ID: 41-52-Mastic

Lab Sample ID: 041504190-0052A

Sample Description: Server Room/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Black	0%	100%	None Detected	

Client Sample ID: 42-53-Floor Tile

Lab Sample ID: 041504190-0053

Sample Description: Server Room/12" Tan w/ Brown FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Brown/Tan	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Brown/Tan	0.0%	100%	None Detected	

Client Sample ID: 42-53-Mastic

Lab Sample ID: 041504190-0053A

Sample Description: Server Room/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Yellow	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Yellow	0.0%	100%	None Detected	

Client Sample ID: 42-54-Floor Tile

Lab Sample ID: 041504190-0054

Sample Description: Server Room/12" Tan w/ Brown FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Brown/Tan	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 42-54-Mastic **Lab Sample ID:** 041504190-0054A
Sample Description: Server Room/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Yellow	0%	100%	None Detected	

Client Sample ID: 43-55-Floor Tile **Lab Sample ID:** 041504190-0055
Sample Description: Room 6C / 6D/9" Tan FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Tan	0%	93%	7% Chrysotile	

Client Sample ID: 43-55-Mastic **Lab Sample ID:** 041504190-0055A
Sample Description: Room 6C / 6D/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015				Stop Positive (Not Analyzed)	
TEM Grav. Reduction	2/25/2015	Yellow	0.0%	98.9%	1.1% Chrysotile	

Client Sample ID: 43-56-Floor Tile **Lab Sample ID:** 041504190-0056
Sample Description: Room 6C / 6D/9" Tan FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015				Stop Positive (Not Analyzed)	

Client Sample ID: 43-56-Mastic **Lab Sample ID:** 041504190-0056A
Sample Description: Room 6C / 6D/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015				Stop Positive (Not Analyzed)	

Client Sample ID: 44-57-Floor Tile **Lab Sample ID:** 041504190-0057
Sample Description: Elevator/Cream FT (Bottom Layer)

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Beige	0%	98%	2% Chrysotile	

Client Sample ID: 44-57-Mastic **Lab Sample ID:** 041504190-0057A
Sample Description: Elevator/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015				Stop Positive (Not Analyzed)	
TEM Grav. Reduction	2/25/2015	Yellow	0.0%	100%	<0.11% Chrysotile	

Client Sample ID: 44-58-Floor Tile **Lab Sample ID:** 041504190-0058
Sample Description: Elevator/Cream FT (Bottom Layer)

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015				Stop Positive (Not Analyzed)	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnaslab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 44-58-Mastic **Lab Sample ID:** 041504190-0058A
Sample Description: Elevator/Mastic

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015					Stop Positive (Not Analyzed)

Client Sample ID: 45-59 **Lab Sample ID:** 041504190-0059
Sample Description: Elevator/12" Lt Green FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Green	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Green	0.0%	100%	None Detected	

Client Sample ID: 45-60 **Lab Sample ID:** 041504190-0060
Sample Description: Elevator/12" Lt Green FT

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Green	0%	100%	None Detected	

Client Sample ID: 46-61 **Lab Sample ID:** 041504190-0061
Sample Description: Exterior/Top Layer Window Caulk

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Brown	0%	100%	None Detected	
TEM Grav. Reduction	2/17/2015	Brown	0.0%	100%	None Detected	

Client Sample ID: 46-62 **Lab Sample ID:** 041504190-0062
Sample Description: Exterior/Top Layer Window Caulk

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Brown	0%	100%	None Detected	

Client Sample ID: 47-63 **Lab Sample ID:** 041504190-0063
Sample Description: Exterior/Window Caulk (Inner Layer)

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray	0%	94%	6% Chrysotile	

Client Sample ID: 47-64 **Lab Sample ID:** 041504190-0064
Sample Description: Exterior/Window Caulk (Inner Layer)

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015					Stop Positive (Not Analyzed)

Client Sample ID: 48-65 **Lab Sample ID:** 041504190-0065
Sample Description: Exterior/Door Caulk

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray	0%	95%	5% Chrysotile	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 041504190
Customer ID: TTIE54
Customer PO: 016993
Project ID: William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Client Sample ID: 48-66 **Lab Sample ID:** 041504190-0066
Sample Description: Exterior/Door Caulk

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015					Stop Positive (Not Analyzed)

Client Sample ID: 49-67 **Lab Sample ID:** 041504190-0067
Sample Description: Exterior/Red Brick Mortar

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray	0%	100%	None Detected	

Client Sample ID: 49-68 **Lab Sample ID:** 041504190-0068
Sample Description: Exterior/Red Brick Mortar

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Gray	0%	100%	None Detected	

Client Sample ID: 50-69 **Lab Sample ID:** 041504190-0069
Sample Description: Exterior/Tan Brick Mortar

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/15/2015	Gray	0%	100%	None Detected	

Client Sample ID: 50-70 **Lab Sample ID:** 041504190-0070
Sample Description: Exterior/Tan Brick Mortar

TEST	Analyzed Date	Color	Non-Asbestos		Asbestos	Comment
			Fibrous	Non-Fibrous		
PLM	2/16/2015	Gray	0%	100%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID:	041504190
Customer ID:	TTIE54
Customer PO:	016993
Project ID:	William Paterson U

Summary Test Report for Asbestos Analysis in Accordance with N.J.A.C. 8:60 and 12:120 via EPA 600/R-93/116

Analyst(s):

Amy Johnson	PLM (40)
Chris Little	TEM Grav. Reduction (3)
Clarissa Turton	PLM (45)
Wayne Froehlich	TEM Grav. Reduction (24)

Reviewed and approved by:



Benjamin Ellis, Laboratory Manager
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. This test report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. EMSL bears no responsibility for sample collection activities or analytical method limitations. The laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples. PLM alone is not consistently reliable in detecting asbestos in floor coverings and similar NOBs.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NVLAP Lab Code 101048-0, AIHA-LAP, LLC-IHLAP Lab 100194, NYS ELAP 10872, NJ DEP 03036

Initial report from: 02/16/2015 09:13:30

PLM Sampling Data and Chain of Custody Record

[illegible]

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-5974

<http://www.EMSL.com>cinnaslab@EMSL.com

EMSL Order: 041507253
CustomerID: TTIE54
CustomerPO: 017165
ProjectID: William Paterson U

Attn: **Michael Stocku**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
Fax: (856) 840-8815
Received: 03/13/15 4:30 PM
Analysis Date: 3/14/2015
Collected: 3/13/2015

Project: 14-1532 / Hunziker Wing

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
01-01-Skim Coat 041507253-0001	First Custodial Slapsink - Wall Plaster- Skim Coat	White Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
01-01-Base Coat 041507253-0001A	First Custodial Slapsink - Wall Plaster- Base Coat	Gray Non-Fibrous Homogeneous		95% Non-fibrous (other) 5% Vermiculite	None Detected
01-02-Skim Coat 041507253-0002	2nd Floor Nursing Dept, Offices 214 - Wall Plaster- Skim Coat	White Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
01-02-Base Coat 041507253-0002A	2nd Floor Nursing Dept, Offices 214 - Wall Plaster- Base Coat	Gray Non-Fibrous Homogeneous		95% Non-fibrous (other) 5% Vermiculite	None Detected
01-03-Skim Coat 041507253-0003	2nd Floor Room 235 - Wall Plaster- Skim Coat	White Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
01-03-Base Coat 041507253-0003A	2nd Floor Room 235 - Wall Plaster- Base Coat	Gray Non-Fibrous Homogeneous		95% Non-fibrous (other) 5% Vermiculite	None Detected

Analyst(s)

Jillian Yurick (4)

Matthew Carralero (2)

Benjamin Ellis, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Reporting limit is 1%.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NVLAP Lab Code 101048-0, AIHA-LAP, LLC-IHLAP Lab 100194, NYS ELAP 10872, NJ DEP 03036, PA ID# 68-00367

Initial report from 03/14/2015 16:04:08



Appendix D

Non Asbestos Material Summary

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

Level	Location	Homogeneous No.	Material Name	Amount
First Floor				
	Auditorium			
		06	2'x2' Fissured Lay-in Ceiling Tile	300 SF
		12	Drywall	1,500 SF
		13	Joint Compound	200 LF
		25	12" Black Floor Tile/Mastic	20 SF
	Classrooms			
		08	Glue Dots associated with Chalkboard	500 SF
	Custodial Slopink			
		06	2'x2' Fissured Lay-in Ceiling Tile	48 SF
		19	12" Black and White Speckled Floor Tile/Mastic	48 SF
	Department of Nursing Main Office 106			
		06	2'x2' Fissured Lay-in Ceiling Tile	520 SF
		12	Drywall	600 SF
		13	Joint Compound	55 SF
		33	Green Cove Base Mastic	120 LF
	Department of Nursing Main Offices 106			
		09	Slate Window Sill	25 SF
	Exterior			
		46	Exterior Window Caulk (Top Layer)	800 LF
		49	Exterior Red Brick Mortar	1,200 SF
		50	Tan Brick Mortar	3,200 SF
	Hallway			
		04	12" Tan Floor Tile/Mastic	1,650 SF
		06	2'x2' Fissured Lay-in Ceiling Tile	1,650 SF
	Learning Center 102			
		05	Black Cove Base Mastic	100 LF
		06	2'x2' Fissured Lay-in Ceiling Tile	720 SF
		09	Slate Window Sill	25 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Men's Restroom			

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
	Men's Restroom			
		06	2'x2' Fissured Lay-in Ceiling Tile	200 SF
		09	Slate Window Sill	20 SF
		19	12" Black and White Speckled Floor Tile/Mastic	15 SF
		23	Ceramic Tile Grout	320 SF
	Nursing Department Learning Center 123			
		04	12" Tan Floor Tile/Mastic	425 SF
		06	2'x2' Fissured Lay-in Ceiling Tile	425 SF
		09	Slate Window Sill	20 SF
		18	Brown Cove Base Mastic	60 LF
	Room 103 Student Success Program			
		05	Black Cove Base Mastic	75 LF
		06	2'x2' Fissured Lay-in Ceiling Tile	320 SF
		09	Slate Window Sill	20 SF
		12	Drywall	125 SF
		13	Joint Compound	20 SF
	Room 104			
		04	12" Tan Floor Tile/Mastic	960 SF
		06	2'x2' Fissured Lay-in Ceiling Tile	960 SF
		09	Slate Window Sill	35 SF
		18	Brown Cove Base Mastic	120 LF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Room 107			
		04	12" Tan Floor Tile/Mastic	1,040 SF
		09	Slate Window Sill	35 SF
		18	Brown Cove Base Mastic	120 LF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Room 108			
		04	12" Tan Floor Tile/Mastic	780 SF
		05	Black Cove Base Mastic	100 LF
		09	Slate Window Sill	25 SF

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
	Room 108			
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
		30	2'x2' Smooth White Lay-in Ceiling Tile	780 SF
	Room 109			
		09	Slate Window Sill	20 SF
	Room 110			
		04	12" Tan Floor Tile/Mastic	150 SF
		05	Black Cove Base Mastic	45 LF
	Room 111			
		05	Black Cove Base Mastic	110 LF
		06	2'x2' Fissured Lay-in Ceiling Tile	835 SF
		09	Slate Window Sill	25 SF
		26	12" Tan with Grey Streaks Floor Tile/Mastic	835 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Room 122			
		04	12" Tan Floor Tile/Mastic	835 SF
		06	2'x2' Fissured Lay-in Ceiling Tile	835 SF
		09	Slate Window Sill	30 SF
		18	Brown Cove Base Mastic	60 LF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Room 124			
		06	2'x2' Fissured Lay-in Ceiling Tile	255 SF
		18	Brown Cove Base Mastic	60 LF
	Room 125			
		09	Slate Window Sill	25 SF
		12	Drywall	300 SF
		13	Joint Compound	20 SF
		27	12" Spline Ceiling Tile	25 SF

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

Level	Location	Homogeneous No.	Material Name	Amount
Ground Floor	Room 125	28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
		30	2'x2' Smooth White Lay-in Ceiling Tile	400 SF
	Room 128	04	12" Tan Floor Tile/Mastic	835 SF
		06	2'x2' Fissured Lay-in Ceiling Tile	835 SF
		09	Slate Window Sill	25 SF
		18	Brown Cove Base Mastic	120 LF
	Room 129	06	2'x2' Fissured Lay-in Ceiling Tile	440 SF
		07	12" Beige Floor Tile/Mastic	440 SF
		09	Slate Window Sill	25 SF
		18	Brown Cove Base Mastic	80 LF
	Room 130	04	12" Tan Floor Tile/Mastic	440 SF
		06	2'x2' Fissured Lay-in Ceiling Tile	440 SF
		09	Slate Window Sill	25 SF
		18	Brown Cove Base Mastic	80 LF
	Throughout	40	Interior Brick Mortar	3,200 SF
	Women's Restroom	06	2'x2' Fissured Lay-in Ceiling Tile	200 SF
		09	Slate Window Sill	20 SF
		23	Ceramic Tile Grout	320 SF
		24	12" Multi-color Speckled Floor Tile/Mastic	15 SF
		25	12" Black Floor Tile/Mastic	15 SF
	10A-G Therapy Suites	05	Black Cove Base Mastic	120 LF
		07	12" Beige Floor Tile/Mastic	830 SF
		09	Slate Window Sill	35 SF
		12	Drywall	650 SF
		13	Joint Compound	45 SF

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

Level	Location	Homogeneous No.	Material Name	Amount
	10A-G Therapy Suites			
		15	2'x4' Lay-in Ceiling Tile	830 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	11E Clinician's Room			
		05	Black Cove Base Mastic	40 LF
		07	12" Beige Floor Tile/Mastic	420 SF
		09	Slate Window Sill	20 SF
		12	Drywall	325 SF
		13	Joint Compound	25 SF
		15	2'x4' Lay-in Ceiling Tile	420 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	4A Speech and Hearing Science Laboratory			
		05	Black Cove Base Mastic	60 LF
		07	12" Beige Floor Tile/Mastic	315 SF
		09	Slate Window Sill	20 SF
		12	Drywall	30 SF
		13	Joint Compound	5 SF
		15	2'x4' Lay-in Ceiling Tile	315 SF
	5A-E Therapy Suites			
		05	Black Cove Base Mastic	110 LF
		07	12" Beige Floor Tile/Mastic	835 SF
		09	Slate Window Sill	35 SF
		12	Drywall	350 SF
		13	Joint Compound	25 LF
		15	2'x4' Lay-in Ceiling Tile	835 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	6A Language Facilitation Computer Lab			
		05	Black Cove Base Mastic	60 LF
		07	12" Beige Floor Tile/Mastic	290 SF
		09	Slate Window Sill	20 SF

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
	6A Language Facilitation Computer Lab			
		12	Drywall	800 SF
		13	Joint Compound	50 LF
		15	2'x4' Lay-in Ceiling Tile	290 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	7A-E Faculty Offices			
		07	12" Beige Floor Tile/Mastic	325 SF
		09	Slate Window Sill	35 SF
		12	Drywall	825 SF
		13	Joint Compound	50 LF
		15	2'x4' Lay-in Ceiling Tile	835 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Classrooms			
		08	Glue Dots associated with Chalkboard	500 SF
	Communication Disorder and Sciences			
		05	Black Cove Base Mastic	120 LF
		07	12" Beige Floor Tile/Mastic	835 SF
		09	Slate Window Sill	35 SF
		12	Drywall	825 SF
		13	Joint Compound	55 SF
		15	2'x4' Lay-in Ceiling Tile	835 SF
	Custodial Break Room			
		12	Drywall	215 SF
		13	Joint Compound	25 SF
	Custodial Slopink			
		05	Black Cove Base Mastic	32 LF
	Custodial Supply Room			
		12	Drywall	215 SF
		13	Joint Compound	25 SF
	Electrical Closet/Storage 26			

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

Level	Location	Homogeneous No.	Material Name	Amount
	Electrical Closet/Storage 26	12	Drywall	80 SF
		13	Joint Compound	10 SF
	Elevator	07	12" Beige Floor Tile/Mastic	35 SF
		45	12" Light Green Floor Tile/Mastic	35 SF
	Exterior	46	Exterior Window Caulk (Top Layer)	800 LF
		49	Exterior Red Brick Mortar	1,200 SF
		50	Tan Brick Mortar	3,200 SF
	Hallway	04	12" Tan Floor Tile/Mastic	1,650 SF
		05	Black Cove Base Mastic	405 LF
		06	2'x2' Fissured Lay-in Ceiling Tile	1,650 SF
	Janitorial Supply Room	12	Drywall	50 SF
		13	Joint Compound	15 SF
	Rear Hall by Storage 26	12	Drywall	450 SF
		13	Joint Compound	50 SF
		16	2'x2' Textured Ceiling Tile	80 SF
	Rear Hallway by Storage 26	05	Black Cove Base Mastic	80 LF
	Room 16	05	Black Cove Base Mastic	70 LF
		06	2'x2' Fissured Lay-in Ceiling Tile	625 SF
		07	12" Beige Floor Tile/Mastic	625 SF
		09	Slate Window Sill	25 SF
	Room 9 Observation Room	05	Black Cove Base Mastic	40 LF
		12	Drywall	325 SF
		13	Joint Compound	35 LF
		15	2'x4' Lay-in Ceiling Tile	150 SF

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

Level	Location	Homogeneous No.	Material Name	Amount
	Rooms 6C/6D			
		05	Black Cove Base Mastic	40 LF
		09	Slate Window Sill	20 SF
		15	2'x4' Lay-in Ceiling Tile	835 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Server Room			
		12	Drywall	300 SF
		13	Joint Compound	30 LF
		42	12" Tan with Brown Streaks Floor Tile/Mastic	25 SF
	Speech and Hearing Clinic 11A-11C			
		05	Black Cove Base Mastic	100 LF
		07	12" Beige Floor Tile/Mastic	835 SF
		09	Slate Window Sill	25 SF
		12	Drywall	400 SF
		13	Joint Compound	25 SF
		15	2'x4' Lay-in Ceiling Tile	835 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Storage across from Janitorial Supply			
		07	12" Beige Floor Tile/Mastic	195 SF
		12	Drywall	195 SF
		13	Joint Compound	30 SF
		15	2'x4' Lay-in Ceiling Tile	195 SF
	Throughout			
		40	Interior Brick Mortar	3,200 SF
	Unassigned Room 23			
		05	Black Cove Base Mastic	40 LF
		12	Drywall	200 SF
		13	Joint Compound	30 SF
Second Floor				
	217 Offices			
		09	Slate Window Sill	35 SF

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
	217 Offices			
		12	Drywall	850 SF
		12	Drywall	850 SF
		13	Joint Compound	75 LF
		13	Joint Compound	75 SF
		16	2'x2' Textured Ceiling Tile	835 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
		37	Gray Cove Base	100 LF
	218 Offices			
		09	Slate Window Sill	35 SF
		16	2'x2' Textured Ceiling Tile	835 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
		37	Gray Cove Base	100 LF
	220 Doctoral Nursing Practice Program			
		09	Slate Window Sill	35 SF
		15	2'x4' Lay-in Ceiling Tile	500 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
		37	Gray Cove Base	80 LF
	220 Drawing Studio			
		06	2'x2' Fissured Lay-in Ceiling Tile	144 SF
	Classrooms			
		08	Glue Dots associated with Chalkboard	500 SF
	Custodial Slopsink			
		06	2'x2' Fissured Lay-in Ceiling Tile	48 SF
		18	Brown Cove Base Mastic	20 LF
		19	12" Black and White Speckled Floor Tile/Mastic	48 SF
	Exterior			
		46	Exterior Window Caulk (Top Layer)	800 LF
		49	Exterior Red Brick Mortar	1,200 SF

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

Level	Location	Homogeneous No.	Material Name	Amount
	Exterior	50	Tan Brick Mortar	3,200 SF
	Hallway	06	2'x2' Fissured Lay-in Ceiling Tile	1,650 SF
	Mechanical Room	35	Brown Duct Insulation	80 SF
	Men's Restroom	09	Slate Window Sill	20 SF
		19	12" Black and White Speckled Floor Tile/Mastic	15 SF
		23	Ceramic Tile Grout	320 SF
		39	12" Tan with Black Specks Floor Tile/Mastic	15 SF
	Nursing Department Offices 214	05	Black Cove Base Mastic	125 LF
		07	12" Beige Floor Tile/Mastic	875 SF
		09	Slate Window Sill	25 SF
		12	Drywall	600 SF
		13	Joint Compound	55 SF
		15	2'x4' Lay-in Ceiling Tile	875 SF
	Room 221	06	2'x2' Fissured Lay-in Ceiling Tile	480 SF
		07	12" Beige Floor Tile/Mastic	480 SF
		09	Slate Window Sill	25 SF
		12	Drywall	200 SF
		13	Joint Compound	15 SF
		18	Brown Cove Base Mastic	80 LF
	Room 232	06	2'x2' Fissured Lay-in Ceiling Tile	835 SF
		07	12" Beige Floor Tile/Mastic	835 SF
		09	Slate Window Sill	35 SF
		18	Brown Cove Base Mastic	60 LF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

Level	Location	Homogeneous No.	Material Name	Amount
Room 233		06	2'x2' Fissured Lay-in Ceiling Tile	835 SF
		07	12" Beige Floor Tile/Mastic	835 SF
		09	Slate Window Sill	35 SF
		18	Brown Cove Base Mastic	60 LF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
Room 234		07	12" Beige Floor Tile/Mastic	150 SF
		18	Brown Cove Base Mastic	40 LF
Room 235		07	12" Beige Floor Tile/Mastic	100 SF
		18	Brown Cove Base Mastic	40 LF
Room 236		05	Black Cove Base Mastic	60 LF
		07	12" Beige Floor Tile/Mastic	145 SF
		09	Slate Window Sill	20 SF
		15	2'x4' Lay-in Ceiling Tile	145 SF
Room 237		06	2'x2' Fissured Lay-in Ceiling Tile	835 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
Room 238		06	2'x2' Fissured Lay-in Ceiling Tile	675 SF
		07	12" Beige Floor Tile/Mastic	675 SF
		18	Brown Cove Base Mastic	60 LF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
Room 239		06	2'x2' Fissured Lay-in Ceiling Tile	835 SF
		07	12" Beige Floor Tile/Mastic	835 SF
		09	Slate Window Sill	35 SF
		27	12" Spline Ceiling Tile	25 SF

Non Asbestos Summary

William Paterson University

Hunziker Wing

Project No: 14-1532

<i>Level</i>	<i>Location</i>	<i>Homogeneous No.</i>	<i>Material Name</i>	<i>Amount</i>
	Room 239			
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Room 240			
		09	Slate Window Sill	35 SF
		12	Drywall	200 SF
		13	Joint Compound	25 LF
		15	2'x4' Lay-in Ceiling Tile	835 SF
		18	Brown Cove Base Mastic	60 LF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Room 241			
		06	2'x2' Fissured Lay-in Ceiling Tile	835 SF
		07	12" Beige Floor Tile/Mastic	835 SF
		09	Slate Window Sill	35 SF
		27	12" Spline Ceiling Tile	25 SF
		28	Glue Dots associated with 12" Spline Ceiling Tile	25 SF
	Throughout			
		40	Interior Brick Mortar	3,200 SF
	Women's Restroom			
		09	Slate Window Sill	20 SF
		23	Ceramic Tile Grout	320 SF
		24	12" Multi-color Speckled Floor Tile/Mastic	15 SF
		38	12" Green with Black Specks Floor Tile/Mastic	15 SF