

## Carriage House Clarification Drawing CL-3 pg-1

DOOR SCHEDULE					
DOOR NO.	SIZE	TYPE	FRAME	RATING	HARDWARE
1.0	3'-0" X 6'-8"	A	2	-	3
2.0	3'-0" X 6'-8"	B	1	-	4
3.0	3'-0" X 6'-8"	C	3	45 MIN	3
4.0	3'-0" X 6'-8"	D	3	-	2
5.0	(2) 3'-6" X 6'-8"	E	3	-	1
6.0	3'-0" X 6'-8"	B	1	-	3

DOOR A - PREFINISHED SOLID CORE WOOD DOOR, 5 PLY CONSTRUCTION, 1-3/4" THICK, MATCHING HARDWARE, WIDTH = 1" TO 1-3/8", PREFINISHED OAK VENEER PLAIN SLICED RED OAK STANDARD STAIN (SS1) (SS2). CONTRACTOR TO SUBMIT (SS1) (SS2) COLOR CHART. BY TRUDDOR, GRAHAM DOORS OR EQUAL.

DOOR B - SIMILAR TO "DOOR A". FLUSH DOOR, NO FULL LITE GLASS.

DOOR C - 1-3/4" FIRE RATED MINERAL CORE WOOD DOOR, 45 MIN WITH FIRE RATED DOOR FRAME. PREFINISHED WITH PLAIN SLICED RED OAK VENEER, STANDARD STAIN (SS1) (SS2) BY TRUDDOR, GRAHAM DOORS OR EQUAL.

DOOR D - JEN WELD SMOOTH FIBERGLASS EXTERIOR DOOR, 2 PANEL EURO PAINTED, COLOR BY ARCHITECT, AURALAST WOOD FRAME.

DOOR E - 16 GAUGE STEEL STIFFENED DOOR ST SERIES DOOR BY MESKER OR EQUAL. PREFINISHED - COLOR BY ARCHITECT.

FRAME 1 - 3 PIECE KNOCKED DOWN DRYWALL FRAME 16 GAUGE COLD ROLLED STEEL, 2" JAMB AND HEAD FACES, EXACT DIE MITE CORNER CONNECTIONS. 14 GAUGE DOOR CLOSER REINFORCEMENT, FACTORY-APPLIED BAKED ON RUST INHIBITING PRIMER BY STEELCRAFT, MESKER, TRUDDOR OR EQUAL.

FRAME 2 - STEEL SIDELITE DOOR FRAME 16 GAUGE, WELDED WITH 12" GLASS SIDE LIGHT, 1/2" TEMPERED GLASS. 5/8" GLASS STOPS. FACTORY-APPLIED RUST INHIBITING PRIMER BY STEELCRAFT, TRUDDOR OR EQUAL.

FRAME 3 - 16 GAUGE WELDED STEEL FRAME, WITH FACTORY APPLIED RUST INHIBITING PRIMER BY MESKER, OR EQUAL. FIRE RATED AS INDICATED.

LOCKSET 1: A 12V POWER SUPPLY WITH 8 RELAYS (SECURITRON AQD4-8F8R2), A REQUEST TO EXIT BUTTON READING, EMERGENCY EXIT AT ADA HEIGHT (SECURITRON EEB2), 2 MAG LOCK INTEGRATED PIR (SECURITRON M680 EBDX), ACCESS CONTROL BANANA CABLE BACK TO CLOSET.

LOCKSET 2: A 12V POWER SUPPLY WITH 8 RELAYS (SECURITRON AQD4-8F8R2), A REQUEST TO EXIT BUTTON READING, EMERGENCY EXIT AT ADA HEIGHT (SECURITRON EEB2), 1 MAG LOCK INTEGRATED PIR (SECURITRON M680 EBDX), ACCESS CONTROL BANANA CABLE BACK TO CLOSET.

LOCKSET 3: ACCESS CONTROL MORTISE LOCKSETS PROVIDED BY OWNER & INSTALLED BY CONTRACTOR IN220-ML20133-IPS-B-NSA-626. THE CONTRACTOR WILL BE RESPONSIBLE FOR INSTALLING WIRE FROM DATA CLOSET TO DOOR FRAME TO LOCKSET MECHANICAL ROOM CLOSER BY LCN.

LOCKSET 4: (2) SETS CORBIN RUSSWIN ML 2030 NSA 626 KEYWAY 77A1.

NOTE: ALL HINGES 4 1/2" BALL BEARING HINGES.



