



WILLIAM PATERSON UNIVERSITY

OFFICE OF CAPITAL PLANNING, DESIGN, AND CONSTRUCTION
300 POMPTON ROAD • WAYNE, NEW JERSEY 07470-2103
973.720.2548 FAX 973.720.2829 • WWW.WPUNJ.EDU

Addendum #3

TO: All Prospective Bidders
DATE: February 27, 2018
PROJECT: Cheng Library Restrooms Renovation (WP-17-04-10)

This addendum forms a part of the contract bidding documents and answers all questions submitted to date regarding the bidding documents.

Questions and Answers:

- Q1. Drawings have notes to reinstall and test fire alarm system devices. The drawings do not show fire alarm strobes and smoke detectors in Restrooms 116 and 117; and, do not show smoke detectors in any of the restrooms. The fire alarm is Simplex, and they do not allow anyone to work on their systems. Therefore, is the fire alarm scope part of the contract? If so, please confirm the quantities of fire alarm devices with the Architect, and the contact person with Simplex.
- A1. The fire alarm scope will not be part of the contractor's scope of work. The University will be responsible for working directly with Simplex on removing and re-installing the fire alarm strobes, and smoke detectors.**
- Q2. The Light Schedule on Drawing A4 calls for LC Lights as in the base bid, and then there is also an alternate LC fixture listed. However, nowhere on the drawings are LC lights indicated. Please clarify.
- A2. There are no LC Light Fixtures in the scope of work.**

This concludes Addendum No. 3